

RECEIVED

MAR 26 1986

PLEASE TYPE OR PRINT IN INK

GLAC
014643

33/4E-26dc
(for official use only)

(1) OWNER:
Name William R. Stanyer
Address 3203 S.W. Vineyard Rd. S
City Milwaukie State OR. 97222

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: Rotary Air Driven
Rotary Mud Dug
Cable Bored
(4) PROPOSED USE (check): Domestic Industrial Municipal
Irrigation Thermal: Withdrawal Reinjection
Other: Piezometric Grounding Test

(5) CASING INSTALLED: Steel Threaded Plastic Welded
6" Diam. from +1 ft. to 34 ft. Gauge .250
" Diam. from ft. to ft. Gauge

LINER INSTALLED: Steel Threaded Plastic Welded
5" Diam. from 8 ft. to 108 ft. Gauge .188

(6) PERFORATIONS: Perforated? Yes No
Size of perforations 75 in. by 8 in.
perforations from 60 ft. to 108 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
19 gal./min. with 100 ft. drawdown after 2 hrs.
Air test gal./min. with drill stem at ft. hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION: Special standards: Yes No
Well seal—Material used Cement 5% Bentonite
Well sealed from land surface to 23 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Amount of sealing material 16 sacks pounds
How was cement grout placed? pumped
Was pump installed? no Type HP Depth ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel: ft.
Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:
County Clackamas SW $\frac{1}{4}$ SE $\frac{1}{4}$ of Section 26 of
Township 3 S, Range 4 E, WM.
(Township is North or South) (Range is East or West)
Tax Lot Lot Block Subdivision

MAILING ADDRESS OF WELL (or nearest address)
Lakehead Trailer Court
Rt. 3 Box 344 Estacada, OR. 97023

(11) WATER LEVEL of COMPLETED WELL:
Depth at which water was first found 8 ft.
Static level 56 ft. below land surface. Date 3-13-86
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 146 ft. Depth of completed well 146 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	1	
Clay	1	8	
Gravel	8	17	
Soft Rock	17	23	
Rock Broken	23	34	
Rock	34	42	
Rock-Gravel Conglomerate	42	56	
Water Bearing Rock	56	116	
Rock	116	146	56

Date work started 3-4-86 /completed 3-13-86
Date well drilling machine moved off of well 3-17 1986

(unbonded) Water Well Constructor Certification (if applicable):
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Date , 19

(bonded) Water Well Constructor Certification:
Bond 9497479 Issued by: Fidelity & Deposit Co.
(number) (Surety Company Name)
On behalf of Donnelly Drilling Co.
(type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:
(Signed) David Donnell
(Water Well Constructor)
(Dated) 3-24-86

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.