

RECEIVED

CLACK
CLACK
015072

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.
SEP 23 1963 WATER WELL REPORT
STATE ENGINEER, SALEM, OREGON (Please type or print)
SALEM OREGON

State Well No. 6/1-2cb
State Permit No.

G-5028

(1) OWNER:

Name FRANK GEHRMAN
Address RTE. 1 BOX 278
MOLALLA OREGON

(2) LOCATION OF WELL:

County CLACKAMAS Driller's well number
Bearing and distance from section or subdivision corner
2400 FT. NORTH + 375 FT. EAST OF S.W. CORNER OF SECTION 2, T. 6 S., R. 1 E. OF M.

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from 2" above to 19' 05" Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CONCRETE
Depth of seal 18 1/2 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? X X Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 0 ft. below land surface Date 8-17-63
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 28 gal./min. with 120 ft. drawdown after 1 1/2 hrs.
Artesian flow g.p.m. Date
Temperature of water X Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 152 ft. Depth of completed well 152 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP-SOIL - DARK BROWN	0	2
CLAY-BROWN	2	8
CLAYSTONE-MED. HARD-GRAY	8	30
APPROX. 1 1/2 G.P.M. AT 30 FT.		
BLACK-BASALT-ROCK-HARD	30	45
" " " " -MED. HARD	45	108
11-G.P.M. BETWEEN 45 FT. + 46 FT.		
CLAYSTONE-MED. HARD-LAVENDER	108	120
CLAYSTONE-GRAY-MED. HARD	120	150
15 1/2 G.P.M. AROUND 130 FT.		
CLAYSTONE-RED-MED. HARD	150	152

Work started AUG 7 1963. Completed AUG 14, 1963
Date well drilling machine moved off of well AUG 14, 1963

(13) PUMP:

Manufacturer's Name UNIVERSAL
Type: SUBMERSIBLE H.P. 3

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. STADELI & SONS
(Person, firm or corporation) (Type or print)

Address RTE. 3, BOX 169, SILVERTON, ORE

Drilling Machine Operator's License No. 16

[Signed] Paul R. Stadel
(Water Well Contractor)

Contractor's License No. 296 Date 6-30, 1964