NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 MAR 2 3 1970 STATE OF OREGON (Please type or print)

within 30 days from the date STATE ENGIDER type or print) of well completion.

SALEM. OREGON

SALEM. OREGON

(1) OWNER:	(11) LOCATION OF WELL: County Clackamas Driller's well number	
Name Chester F. Dahl		
Address Rtl, Box 297	SE 4 SE 4 Section 3 T. 6S	R. 1E W.M.
Melalla, Oregon 97038	Bearing and distance from section or subdivision	corner
(2) TYPE OF WORK (check):	Bearing and distance from basics of basics	
New Well ☐ Deepening ☐ Reconditioning ☐ Abandon ☐		
If abandonment, describe material and procedure in Item 12.		-
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(19) WELL LOC.	6
Rotary Driven Domestic A Industrial Municipal D	(12) WELL LOG: Diameter of well b	elow casing
Cable N Jetted Donestic Industrial Industrial Donestic Industrial Indus	Depth drilled 166 ft. Depth of comple	eted well 166 ft.
CASING INSTALLED: Threaded Welded To Gage 250	Formation: Describe color, texture, grain size a and show thickness and nature of each stratur with at least one entry for each change of formatin position of Static Water Level as drilling pro	m and aquifer penetrated, ation. Report each change
	MATERIAL	From To SWL
	Tep seil	0 2
A DADLO DA ATAONIC	Clay, brown	2 13
PERFORATIONS: Perforated? ☐ Yes 🛣 No.	Decemeposed rock	13 16
ype of perforator used	Shale, hard, green	16 28
Size of perforations in. by in.	Sandstone, formation	28 72
perforations from ft. to ft.	red	
perforations from ft. to ft.	Rock, grey, red seams	72 138
perforations from ft. to ft.	Rock, grey	138 155 0
perforations from ft. to ft.	Reck, grew to green	155 160
perforations from ft. to ft.	Rack , grey to red	160 166
(7) SCREENS: Well screen installed? ☐ Yes 【本No Manufacturer's Name		
Type Model No.		
Diam. Slot size Set from ft. to ft.		
Diam. Slot size Set from ft. to ft.		
Diani		
(8) WATER LEVEL: Completed well. Static level 0 ft. below land surface Date 3/12/70		
sian pressure lbs. per square inch Date		
(9) WELL TESTS: Drawdown is amount water level is lowered below static level		
Was a pump test made? No If yes, by whom? Driller		
eld: 50 gal./min. with 24 ft. drawdown after 2 hrs.	Work started 2/26 1970 Complete	ed 3/13 1970
gar/mm. water 1t. drawdown after miss.	Date well drilling machine moved off of well	3/13 1970
	Davis No. 11 Constant Continue	
" " " "	Drilling Machine Operator's Certification: This well was constructed under my di	rect supervision. Mate-
Bailer test gal./min. with ft. drawdown after hrs.	rials used and information reported above	e are true to my best
Artesian flow g.p.m. Date	knowledge and belief.	0/7
Temperature of water 5 ⁴ Was a chemical analysis made? ☐ Yes ☐ No	[Signed]	Date 3/13, 19 70
(10) CONSTRUCTION:	Drilling Machine Operator's License No	86
Well seal—Material used Bestonite		
Depth of sealft.	Water Well Contractor's Certification:	
Diameter of well bore to bottom of sealin.	This well was drilled under my jurisdi	ction and this report is
Were any loose strata cemented off? Yes X No Depth	true to the best of my knowledge and believed the control of the c	7L.
Was a drive shoe used? ☐ Yes ☐ No	NAME (Person, firm or corporation)	(Type or print)
Did any strata contain unusable water? Yes No	Address Rt. 1, Bex 151, Mu	lima. Oracan
Type of water? depth of strata	Address 10 1 10 10 110	
Method of sealing strata off	[Signed] (S. Westerland	·
Was well gravel packed? Yes No Size of gravel:	(Water Well Contrac	
Gravel placed from ft. to ft.	Contractor's License No. 86 Date	3/13 , 1970