

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT 015129 DEC 6 1967 STATE OF OREGON (Please type or print) STATE ENGINEER SALEM, OREGON

CLAC 015129

State Well No. 6/10-4 A State Permit No.

(1) OWNER:

Name Martin Schneider Address Rte.1, Mt. Angel, Oregon

(2) LOCATION OF WELL:

County Clackamas Driller's well number approx. 1/4 Section T. R. W.M. Bearing and distance from section or subdivision corner 540 ft. north & 600 ft. east of S.W. corner of section 4, T.6 S., R.1 W.

(3) TYPE OF WORK (check):

Well [X] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other [] Rotary [X] Driven [] Cable [] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

8" Diam. from 0 ft. to 51 ft. Gage 250 Threaded [] Welded [X]

(7) PERFORATIONS:

Perforated? [] Yes [X] No Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal-Material used in seal Bentonite & cuttings Depth of seal 51 ft. Was a packer used? no Diameter of well bore to bottom of seal 12 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [] Yes [X] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 49 ft. below land surface Date 7/6/67 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [X] No If yes, by whom? Yield: 200 gal./min. with 41 ft. drawdown after 1 hr. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water XX Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Diameter of well below casing 7-7/8" Depth drilled 106 ft. Depth of completed well 97 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Top soil-brown, Clay - light brown, Rock - grey-med. hard, Sandstone-brown, Rock-brown,hard, Rock-brown, soft, Claystone-grey- soft, Claystone-grey- hard, Sandstone- grey- hard, Claystone- grey- med. hard, Claystone- grey-hard, crevicy- Water- bearing-

Work started July 6 1967 Completed July 7, 1967 Date well drilling machine moved off of well July 7, 1967

(13) PUMP:

Manufacturer's Name ? Type: Water lubed Turbine H.P. ?

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadel & Sons (Person, firm or corporation) (Type or print) Address Rte. 3, Box 169, Oregon Silverton, Ore. 97381 Drilling Machine Operator's License No. 322 [Signed] Paul R. Stadel (Water Well Contractor) Contractor's License No. 296 Date 9/29/67 19.....