NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

CLAC State Well No. COS/1E-59

(Please type or print) (Please type or print) 015143

State Permit No. ..

(1) OWNED.	(10) LOCATION OF WELL:		-
(1) OWNER:			
Name Verl Jacobsen Address RFD 2 Box 214			
Woodburn, Oregon 97071	½ N.E. ¼ Section 5 T. 6S R. 1E W.M.		
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision	on corner	
New Well M Deepening □ Reconditioning □ Abandon □			
If abandonment, describe material and procedure in Item 12.	(11) WARRED I RIVER . Completed as	_ 11	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL: Completed well.		
Ratary M Driven [7	Depth at which water was first found 235 ft. Static level 44 ft. below land surface. Date 8/30/78		
Cable	State level 11. below land surface. Date 77571		
Dug Bored Irrigation Test Well Other	Artesian pressure lbs. per squar	e inch. Date	· · · · · · · · · · · · · · · · · · ·
CASING INSTALLED: Threaded Welded 10 mg Diam. from plus 1 ft. to 190 ft. Gage 250	(12) WELL LOG: Diameter of well b	_	
	Depth drilled 585 ft. Depth of comple		585 ft.
ft. To ft. Gage ft. Gage	Formation: Describe color, texture, grain size a and show thickness and nature of each stratus		
PERFORATIONS: Perforated? Yes No.	with at least one entry for each change of format position of Static Water Level and indicate prin	tion. Report e	ach change in
pe of perforator used	MATERIAL	From 7	To SWL
Size of perforations in. by in.	Top Soil Brown	0	1
perforations from ft. to ft.	Clay Brown		19
perforations from ft. to ft.	Conglemerate Medium Brown		24
perforations from ft. to ft.	Conglemerate Course Brown		90
(7) SCREENS: Well screen installed? ☐ Yes ♣ No	Clay Sandy Grey		75
Manufacturer's Name	Clay Sandy Yellow		35
Type Model No.	Sandstone Hard Grey		90
Diam Slot size Set from ft. to ft.	Spandstone		
Diam. Slot size Set from ft. to ft.	Sandstone Hard Green	190 4	09 W.B.
(8) WELL TESTS: Drawdown is amount water level is	Sandstene Grey Hard		10
lowered below static level	Sandstone Medium Grey	510 5	35 W.B.
Was a pump test made? K Yes \(\square\) No If yes, by whom? Stettler			
Yield: 400 gal./min. with 220 ft. drawdown after 4 hrs.			
, n n	10" te 300 ft.		
n n	8" from 300 ft. to 585 ft.		
Bailer test gal./min. with ft. drawdown after hrs.			···
Artesian flow g.p.m.			
erature of water Depth artesian flow encountered ft.	Work started 8/19 19 78 Complete	ed 8/	30 ₁₉ 78
(9) CONSTRUCTION:	Date well drilling machine moved off of well	8/:	30 ₁₉ 78
Well seal—Material used	Drilling Machine Operator's Certification:		
Well sealed from land surface toft.	This well was constructed under my Materials used and information reported		
Diameter of well bore to bottom of seal in.	best knowledge and belief		-
Diameter of well bore below seal	[Signed] Chuch Stadis	Date9/2	28 ₁₉ 78
Number of sacks of cement used in well seal 8acks	(Drilling Machine Operator) Drilling Machine Operator's License No		
How was cement grout placed? Gravity	Drining Machine Operator's License No.	1.56.2	
· · · · · · · · · · · · · · · · · · ·	Water Well Contractor's Certification:		
	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Was a drive shoe used? Yes X No Plugs Size: location ft.	Name West Coast Drilling Co., Inc. (Person, firm or corporation) (Type or print)		
Did any strata contain unusable water? 🗌 Yes 🕱 No			
Type of water? depth of strata	Address Mt. Angel, Oregon - 220) Academ	z St., 973
Method of sealing strata off	[Signed] (March E)	The La	
Was well gravel packed? Tyes X No Size of gravel:	(Water Well Contr.	actor)	
Gravel placed fromft. toft.	Contractor's License No519 Date	9/28	19 7 8