NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

State Well No. 65/155

WATER RESOURCES DEPARTMENTED 7 1978 STATE OF OREGONNOV 2 S 1978 State Well No. SALEM, OREGON 97310 (Please type or print) within 30 days from the dater RESOURCES DEPT. Permit No. OF GON SALEM, OREGON SALEM. OREGON

(1) OWNER:	(10) LOCATION OF WELL:		
Name Fessler Farms #1	County Clackamas Driller's well nu	ımber	
Address RT. 2 Bex 282 Woodburn Oregon	sw 14 ne 14 Section 5 T. 6s	R. 1E	W.M.
(a) THE OF WORK (1 I)	Bearing and distance from section or subdivisi	on corner	
(2) TYPE OF WORK (check):			
New Well Deepening Reconditioning Abandon Reconditioning Abandon			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	ell.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 241		ft.
Rotary 💆 Driven 🗌 Domestic 🗌 Industrial 🗎 Municipal 🗎	Static level 60 ft. below land s	urface. Date	2-7-78
Dug Bored Irrigation X Test Well Other	Artesian pressure lbs. per squar	e inch. Date	
CASING INSTALLED: Threaded Welded M. 12 "Diam. from plus 1 ft. to 74 ft. Gage 250 250	(12) WELL LOG: Diameter of well below casing Depth drilled 290 ft. Depth of completed well 290 ft.		
10 " Diam. from - 20 ft. to 290 ft. Gage •250	Formation: Describe color, texture, grain size	and structure	of materials;
PERFORATIONS: Perforated? Ves K No.	and show thickness and nature of each stratu with at least one entry for each change of forma position of Static Water Level and indicate prin	m and aquifer tion. Report ea	penetrated,
PERFORATIONS: Perforated? Yes No. Spe of perforator used torche liner is perforated	MATERIAL	From To	<u> </u>
Size of perforations 3-16 in. by 4 in.	Top _{soil} Brn	0 1	SWL
460 perforations from 240 ft. to 290 ft.	CLAY Brown	1 10	<u>, </u>
perforations fromft. toft.	Basalt Brn & Grey Fract.	10 28	'
perforations from ft. to ft.	Glay Grey Sticky	28 31	
	Clay Brn	31 65	
(7) SCREENS: Well screen installed? Yes No	Basalt Grey Med	65 71	
Manufacturer's Name	Basalt Grey Hard	71 112	
Type Model No. Diam. ft. to ft.	Clay Grey	112 165	
Diam. Slot size Set from ft. to ft.	Claystone Grey&Blue Med Clay Grey	165 191 191 240	
	Sandstone Grey Hard	240 290	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level			
Was a pump test made? X Yes 🗆 No If yes, by whom? Stetler			
Yield: 1200 gal./min. with 140 ft. drawdown after 4 hrs.		 	
" " "	4.4.4	 	
<u></u>			
Bailer test gal./min, with ft. drawdown after hrs.	**************************************		
Artesian flow g.p.m.			
perature of water Depth artesian flow encountered ft.	Work started 1-25- 1978 Complete	ed 2-7-78	199
(9) CONSTRUCTION:	Date well drilling machine moved off of well	2-11-78	Ψ
Well seal—Material used Cement Grout	Drilling Machine Operator's Certification:		
Well sealed from land surface to 74 ft.	This well was constructed under my	direct sun	ervision.
Diameter of well bore to bottom of seal 16 in.	Materials used and information reported best knowledge and belief.	above are t	rue to my
Diameter of well bore below seal 124 in.	[Signed] Church State!	Date 8-18	10 78
Number of sacks of cement used in well sealsacks	(Drilling Machine Operator)		
How was cement grout placed? gravity	Drilling Machine Operator's License No.	720	
/	Water Well Contractor's Certification:		
	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Was a drive shoe used? 🗌 Yes 🏿 No Plugs Size: location ft.	Name West Coast Drilling Co.		
Did any strata contain unusable water? Yes X No	(Person, firm or corporation) Address 220/Academy St. M.// Ap	(Type or	
Type of water? depth of strata	Address 220/Academy St. M. A.	ngel Ore.	***************
Method of sealing strata off	[Signed] Charles Collaboration	Celi.	
Was well gravel packed? 🗋 Yes 🅇 No 🚬 Size of gravel:	(Water Well Contr	actor)	
Gravel placed from ft. to ft.	Contractor's License No519 Date	3-14-78	19