

STATE OF OREGON
WATER WELL REPORT
 (as required by ORS 537.765)

RECEIVED

MAY 01 1986

CLAC
 015514

65/3E-6dd

(1) OWNER:
 Name First Covenant Church
 Address 107 N. E. 45th Avenue
 City Portland State Oregon Zip 97213

(2) TYPE OF WORK:
 New Well Deepen Recondition Abandon

(3) DRILL METHOD:
 Rotary Air Rotary Mud Cable Other

(4) PROPOSED USE:
 Domestic Community Industrial Irrigation
 Thermal Injection Other

BORE HOLE CONSTRUCTION:
 Depth of Completed Well 100 ft.
 Special Standards date of approval _____

| HOLE Diameter | From | To | SEAL Material | From | To | Amount sacks or pounds |
|---------------|------|----|---------------|------|----|------------------------|
| | | | | | | |
| | 0 | 50 | | 0 | 50 | |

How was seal placed? Method A B C D E
 Other _____
 Backfill placed from _____ ft. to _____ ft. Material _____
 Gravel placed from _____ ft. to _____ ft. Size of gravel _____

(6) CASING/LINER:

| Diameter | From | To | Gauge | Steel | Plastic | Welded | Threaded |
|------------|------|-----|---------|-------------------------------------|-------------------------------------|-------------------------------------|--------------------------|
| Casing: 6" | +1 | 55 | .250 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Liner: 4" | 0 | 100 | PVC 200 | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

Final location of shoe(s) 55"

PERFORATIONS/SCREENS:

Perforations Method Drill
 Screens Type _____ Material _____

| From | To | Slot size | Number | Diameter | Tele/pipe size | Casing | Liner |
|------|-----|-----------|--------|----------|----------------|--------------------------|-------------------------------------|
| | 100 | | 60 | 1/2 | | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

(8) WELL TESTS: Minimum testing time is 1 hour

| Yield gal/min | Pumping level | Drill stem at | Time |
|---------------|---------------|---------------|--------|
| 55 | | 100 | 1/2 hr |
| 50 | | 80 | 1 hr |
| 24 | | 40 | 1 hr. |

Temperature of water _____ Depth Artesian Flow Found _____
 Was a water analysis done? Yes By whom _____
 Did any strata contain water not suitable for intended use? Too little
 Salty Muddy Odor Colored Other _____
 Depth of strata: _____

(9) LOCATION OF WELL by legal description: (SEE NOTE)
 County Clackamas Latitude _____ " Longitude _____ "
 Township 6 S N or S, Range 3 W E E or W, WM.
 Section 6 SE 1/4 SE 1/4
 Tax Lot _____ Lot _____ Block _____ Subdivision _____
 Street Address of Well (or nearest address) Molalla Retreat, Dickie Prairie Rd.

(10) STATIC WATER LEVEL:
14 ft. below land surface. Date 4/29/86
 Artesian pressure _____ lb. per square inch. Date _____

(11) WELL LOG: Ground elevation _____

| Material | From | To | WB? | SWL |
|--|------|----|-----|----------|
| Brown sandy clay-occ. cobble | | 0 | 4 | |
| Brown sand & gravel-semi cemented | | 4 | 8 | |
| Brown mud flow stone- occ. loose | | 8 | 14 | |
| Brown mud flow stone, firm | | 14 | 50 | |
| Blue-black mud flow stone occ. hard, occ. broken | | 50 | 100 | 55gpm 14 |

Date started 4/23/86 Completed 4/28/86

(unbonded) Water Well Constructor Certification:
 I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.
 Signed _____ Date _____

(bonded) Water Well Constructor Certification:
 I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.
 Signed [Signature] Date 4/30/86
 Company A.M. JANNSEN WELL DRILLING Co. Job No. _____

First Covenant Church 65/3E-6dd

Water Resources Department

Please note: ?

1. Map Location - Pitmon Map, 1977

SE $\frac{1}{4}$ SE $\frac{1}{4}$ Section 6 Tp. 6 S, R 3 EWM

2. Owner's legal description -

Government #2-3 Sec. 3, T6S R 3 EWM

TAX LOTS: 1300, 1400, 1501 LOT: 1-6 Block 2

SUB DIVISION: GLEN HAUGEN

[Handwritten signature]