STATE OF OREGON NOV 1 2 1974 State Well No. 65/6E-1566 STATE ENGINEER, SALEM, OREGON 9
within 30 days from the distribution (Please type or print) STATE ENGINEERState Permit No. (No not write above this liSALEM. OREGON of well completion. (1) OWNER: (10) LOCATION OF WELL: County Clackamas Name U.S. Dept. of Agriculture-Forest Service Driller's well number Address 2440 S. E. 195th, Portland, Or. 97223 NW 14 NW 14 Section 15 T. 6S R. 6E Bearing and distance from section or subdivision corner (2) TYPE OF WORK (check): Riverside Campground New Well Deepening [Reconditioning [If abandonment, describe material and procedure in Item 12. (11) WATER LEVEL: Completed well. (3) TYPE OF WELL: (4) PROPOSED USE (check): Depth at which water was first found Rotary Driven 🖂 ft. below land surface. Date 10/14, Domestic X Industrial | Municipal | Static level Cable Jetted [7] Bored 🗆 Dug Irrigation

Test Well
Other Artesian pressure lbs. per square inch. Date CASING INSTALLED: Threaded | Welded | Diameter of well below casing 6 inch (12) WELL LOG: 6." Diam. from 0 ft. to 42 ft. Gage 0.250 150 ft. Depth of completed well " Diam. from ft. to ft. Gage Formation: Describe color, texture, grain size and structure of materials: and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in PERFORATIONS: position of Static Water Level and indicate principal water-bearing strata. Perforated? Yes | No. pe of perforator used Slotted with cutting torch MATERIAL SWT. Size of perforations 1/4 in. by Clay, brown, sandy 8 8 12 perforations from 35 ft. to 41 ft. Gravel and boulders, cemented 31 14 Rock, blue-med. hard 31 80 perforations from ft. to ft. 80 115 Rock, grey-med, hard ... perforations from ft. to Rock, bluish grey, med. hard (7) SCREENS: Well screen installed?

Yes Yes No Manufacturer's Name Diam. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft. Drawdown is amount water level is lowered below static level (8) WELL TESTS: Was a pump test made? Yes No If yes, by whom? Yield: ft. drawdown after gal./min. with hrs. gal./min. with 136 ft. drawdown after 2 hrs. Bailer test g.p.m. Inperature of water 490 Depth artesian flow encountered ft. Oct. 1h Work started Sept. 19 19 74 Completed Date well drilling machine moved off of well (9) CONSTRUCTION: Well seal-Material used Cement grout Drilling Machine Operator's Certification: This well was constructed under my direct supervision. Well sealed from land surface to ... Materials used and information reported above are true to my best knowledge and belief.
[Signed] Tobert & McConnell Oct. 16, 1974 Diameter of well bore below seal ______ in. to 42 ft. (Drilling Machine Operator) Number of sacks of cement used in well seal Number of sacks of bentonite used in well seal Brand name of bentonite Water Well Contractor's Certification: Number of pounds of bentonite per 100 gallons This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Was a drive shoe used? ី Yes 🗌 No Plugs Size: location ft. Name Steinman Bros.
(Person, firm or corporation) Did any strata contain unusable water?

Yes

No Address 14912 S. E. Kellogg Ave., Type of water? depth of strata Method of sealing strata off Was well gravel packed? K Yes I No Size of gravel: 3/4 minus Contractor's License No. I Date Oct. 16 (USE ADDITIONAL SHEETS IF NECESSARY)

WATER WELL REPORT

NOTICE TO WATER WELL CONTRACTOR The original and first copy

of this report are to be filed with the