

RECEIVED

CLAC
015848

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

APR 4 1966

WATER WELL REPORT

State Well No. 3/4-11

STATE ENGINEER, SALEM, OREGON 97310

STATE ENGINEER OF OREGON
SALEM OREGON (Please type or print)

State Permit No.

(1) OWNER:

Name CLACKAMAS COUNTY PARKS
Address EAGLE FERN PARK
ESTACADA OREGON

(2) LOCATION OF WELL:

County CLACKAMAS Driller's well number
1/4 Section 11 T. 3S R. 4E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded

" Diam. from NONE ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used

Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal NONE OR UNKNOWN
Depth of seal UNKNOWN ft. Was a packer used? N.D.
Diameter of well bore to bottom of seal UNKNOWN in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 7 ft. below land surface Date MAR 21, 66
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " "
" " " " "
" " " " "
Baller test 7 gal./min. with TOTAL drawdown after 1 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 52 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 6 IN.

Depth drilled 146 ft. Depth of completed well 146 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
UNKNOWN	0	66
SOFT LAVA	66	93
RED CLAYSTONE	93	136
SOFT BLACK LAVA	136	146

WELL MADE 7GPM AT START OF DEEPENING JOB
NO WATER WAS FOUND BY DEEPENING

Work started MAR. 21 19 66 Completed MAR. 25 19 66
Date well drilling machine moved off of well MAR 26 19 66

(13) PUMP:

Manufacturer's Name VACCUZZI
Type: JET H.P. 2

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLIAM J. STENNETT
(Person, firm or corporation) (Type or print)

Address 361 WARNER MILNE ROAD, ORE CITY

Drilling Machine Operator's License No. 170-171

[Signed] William J. Stennett
(Water Well Contractor)

Contractor's License No. 5 Date April 1, 1966