

STATE OF OREGON  
**WATER WELL REPORT**  
 (as required by ORS 537.765)

**RECEIVED**

**CLAC**  
**015873**

3-14E-14da

JAN 26 1987

**(1) OWNER:** Owner's Well Number: \_\_\_\_\_  
 Name Eagle Fern Youth Camp **WATER RESOURCES DEPT.**  
 Address 37680 S. E. Camp Dr. **SALEM, OREGON**  
 City Estacada State OR. Zip 97023

**(9) LOCATION OF WELL by legal description:**  
 County Clackamas Latitude \_\_\_\_\_ Longitude \_\_\_\_\_  
 Township 3 ~~N~~ or S, Range 4 E or W, WM.  
 Section 14 ~~NEXE~~  $\frac{1}{4}$  SE  $\frac{1}{4}$   
 Tax Lot \_\_\_\_\_ Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
 Street Address of Well (or nearest address) same

**(2) TYPE OF WORK:**  
 New Well  Deepen  Recondition  Abandon

**(3) DRILL METHOD:**  
 Rotary Air  Rotary Mud  Cable  Other

**(4) PROPOSED USE:**  
 Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Other

**(5) BORE HOLE CONSTRUCTION:**  
 Depth of Completed Well 120 ft.  
 Special Standards date of approval \_\_\_\_\_

HOLE		SEAL		Amount	
Diameter	From To	Material	From To	sacks	pounds
10	0 36	Cement	20 36	9	sacks
		Bentonite	0 20	10	sacks
6	36 120				

How was seal placed? Method  A  B  C  D  E  
 Other \_\_\_\_\_

Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
 Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Size of gravel \_\_\_\_\_

**(6) CASING/LINER:**

	Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing:	6	+1	38	250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner:	4	0	120	160	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) \_\_\_\_\_

**(7) PERFORATIONS/SCREENS:**  
 Perforations Method Saw  
 Screens Type \_\_\_\_\_ Material \_\_\_\_\_

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
10	120	3/4" x 1/4"	100	4"		<input type="checkbox"/>	<input checked="" type="checkbox"/>

**(8) WELL TESTS: Minimum testing time is 1 hour**  
 Pump  Bailer  Air  Flowing Artesian  
 Yield gal/min 20 Pumping level \_\_\_\_\_ Drill stem at 110 Time 1 hr

Temperature of water \_\_\_\_\_ Depth Artesian Flow Found \_\_\_\_\_  
 Was a water analysis done?  Yes By whom \_\_\_\_\_  
 Did any strata contain water not suitable for intended use?  Too little  
 Salty  Muddy  Odor  Colored  Other \_\_\_\_\_  
 Depth of strata: \_\_\_\_\_

**(10) STATIC WATER LEVEL:**  
8 ft. below land surface. Date 1-9-87  
 Artesian pressure \_\_\_\_\_ lb. per square inch. Date \_\_\_\_\_

**(11) WELL LOG:** Ground elevation \_\_\_\_\_

Material	From	To	WB?	SWL
Top Soil	0	1		
Boulders	1	20		
Rock soft	20	30		
Rock	30	60		
Rock	60	100	X	8
Rock soft	100	120		

Date started 11-14-86 Completed 1-15-87

**(unbonded) Water Well Constructor Certification:**  
 I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed \_\_\_\_\_ Date \_\_\_\_\_

**(bonded) Water Well Constructor Certification:**  
 I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.

Signed David Donnelly Date 1-22-87

Company Donnelly Drilling Co. Co. Job No. \_\_\_\_\_