NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

CLAC 015967

RECEIVED JAN 27 1975 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. 3S/4E-16ac
State Permit No.

(1) OWNER:
Name ART ERICKSON
Address RT 1 BOX 172 R ESTACADA

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:
Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 80 ft. Gage 250
5" Diam. from 70 ft. to 125 ft. Gage 18
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:
Perforated? ☒ Yes ☐ No.
Type of perforator used TORCH
Size of perforations 1/8 in. by 10 in.
37 perforations from 90 ft. to 125 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 12 gal./min. with 15 ft. drawdown after 2 hrs.
Artesian flow g.p.m.
Temperature of water 52 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used CEMENT
Well sealed from land surface to 35 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 6 sacks
Number of sacks of bentonite used in well seal — sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water — lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County CLACKAMAS Driller's well number
SW ¼ NE ¼ Section 16 T. 3S R. 4E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 19 ft.
Static level 81 ft. below land surface. Date 12/29/74
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 125 ft. Depth of completed well 125 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
SOIL	0	3	
RED CLAY & BOULDERS	3	22	6
RED SANDY CLAY	22	56	
GRAY SANDY CLAY	56	98	81
BROWN CLAY	98	125	

Work started 12/15 1974 Completed 12/29 1974
Date well drilling machine moved off of well 12/30 1974

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Wallace L. Saarsland Date 1/24, 1975
(Drilling Machine Operator)
Drilling Machine Operator's License No. 380

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name GAARSLAND DRILLING CO
(Person, firm or corporation) (Type or print)
Address P.O. BOX 31 EAGLE CREEK 97022
[Signed] Wallace L. Saarsland
(Water Well Contractor)
Contractor's License No. 543 Date 1/24, 1975

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45658-119