NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

CLAC 16369

State Well No. 3/2-35

State Permit No.

RECEIVED FEB 4 1965 STATE ENGINEER SALEM, OREGON

(1) OWNER:
Name BEAVER CREEK TELEPHONE CO.
Address BEAVER CREEK OREGON

(2) LOCATION OF WELL:
County CLACKAMAS Driller's well number
¼ ¼ Section 35 T. 3S R. 2E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 81'4" ft. Gage 17.02 #
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☐ Yes ☒ No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal CEMENT-BENTONITE
Depth of seal 40 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusuable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 47' ft. below land surface Date 2/2/65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 9 gal./min. with 20 ft. drawdown after 2 hrs.
Artesian flow g.p.m. Date
Temperature of water 53 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 82 ft. Depth of completed well 81 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
TOPSOIL	0	4
RED CLAY WITH		
LAVA CHUNKS	4	22
BOARING LAVA	22	60
YELLOW CLAY	60	65
BORING LAVA-	65	82
BROKEN-WATER		
BEARING		

Work started JAN 22 1965 Completed FEB 1 1965
Date well drilling machine moved off of well FEB 3 1965

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME WILLIAM J STENNETT (Person, firm or corporation) (Type or print)
Address 361 WARNER MILNE RD. ORE CITY
Drilling Machine Operator's License No. 170-171
[Signed] William J. Stennett (Water Well Contractor)
Contractor's License No. 5 Date Feb 3, 1965

(USE ADDITIONAL SHEETS IF NECESSARY)