

NOTICE TO WATER WELL CONTRACTORS
The original and first copy
of this report are to be
filed with the

APR 8 1969

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON

(Please type or print)

(Do not write above this line)

State Well No. 3/3-30

State Permit No. CLAG #17006

(1) OWNER:

Name CLEO WIGGET
Address RT ONE, BOX 50, BEAVERCREEK

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:

Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 36 ft. Gage 17002
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☐ Yes ☒ No.

of perforator used

Size of perforations	in.	by	in.
perforations from	ft.	to	ft.
perforations from	ft.	to	ft.
perforations from	ft.	to	ft.
perforations from	ft.	to	ft.
perforations from	ft.	to	ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 151 ft. below land surface Date 3/25/69
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
" " " " " "

Bailer test 32 gal./min. with 10 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date

Temperature of water 53 Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:

Well seal—Material used BENTONITE
Depth of seal 36 ft.
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☐ Yes ☒ No
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County CLATSOP Driller's well number
1/4 1/4 Section 30 T. 3S. R. 3E W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 285 ft. Depth of completed well 285 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change
in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
RED CLAY	0	28	
HARD GREY ROCK	28	36	
HARD GREY ROCK	36	80	
FINE GRAINED			
DARKER COLORED	80	86	
GREY HARD ROCK	86	104	
SEAM AT	104		
SEAM TRACE OF	107		40
WATER			
SEAMS AT	195		
SEAMS AT	216		
ROCK FROM HARD	104	266	
GREY AVERAGE			
FOOTAGE 1 1/2 FT. H.R.			
SOFTER GREY	266	271	
BLACK AND BROWN	271	280	151
PUMICE ROCK			
WATER BEARING	271	282	
HARD GREY ROCK	282	285	

Work started FEB 16 19 69 Completed MAR 23 1969

Date well drilling machine moved off of well MAR 31 1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] William J. Stennett Date April 4, 1969
(Drilling Machine Operator)

Drilling Machine Operator's License No. 170

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME W. J. STENNETT
(Person, firm or corporation) (Type or print)

Address 361 WARNER MILNE ROAD ORE CITY

[Signed] William J. Stennett
(Water Well Contractor)

Contractor's License No. 5 Date April 4, 1969