

RECEIVED

CLAC  
19266

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

MAR 2 1966 WATER WELL REPORT

State Well No. 3/2-6 N

STATE ENGINEER, SALEM, OREGON STATE OF OREGON  
within 30 days from the date of well completion. SALEM OREGON (Please type or print)

State Permit No. G 3424

(1) OWNER:

Name CLIFFORD CHAPIN  
Address RT ONE BOX 303  
OREGON CITY OREGON

(2) LOCATION OF WELL:

County CLACKAMAS Driller's well number  
1/4 Section 6 T. 35 R. 2E W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other   
Rotary  Cable  Dug  Driven  Jetted  Bored

(6) CASING INSTALLED:

Threaded  Welded   
8" Diam. from 0 ft. to 25'4" ft. Gage 1/2"  
6" Diam. from 0 ft. to 191 ft. Gage 1/4"  
" Diam. from " ft. to " ft. Gage "

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used TORCH CUT  
Size of perforations 1/4 in. by 12 in.  
20 perforations from 10.0 ft. to 11.0 ft.  
30 perforations from 14.0 ft. to 15.0 ft.  
40 perforations from 15.0 ft. to 17.0 ft.  
80 perforations from 17.0 ft. to 18.0 ft.

(8) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name  
Model No.  
Slot size Set from " ft. to " ft.  
Diam. Slot size Set from " ft. to " ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT  
Depth of seal 19 ft. Was a packer used? NO  
Diameter of well bore to bottom of seal 12 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from " ft. to " ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level 42 ft. below land surface Date 2/11/66  
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? BECKERS  
Yield: 140 gal./min. with 50 ft. drawdown after 4 hrs.  
" 275 " 80 " 3 1/2 "  
" " " " " "  
Bailer test 40 gal./min. with NO ft. drawdown after 1 hrs.  
Artesian flow g.p.m. Date  
Temperature of water 54 Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 6  
Depth drilled 191 ft. Depth of completed well 191 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	2
HARD RED CLAY	2	12
SOFT YELLOW CLAY	12	19
GREY BURRING LAVA	19	48
STICKY RED CLAY	48	75
YELLOW SANDY CLAY	75	90
BROWN SAND STONE	90	118
WATER BEARING 35GPM		
STATIC 20'		
BLUE CLAY	118	140
SANDY BROWN CLAY	140	155
LIGHT BROWN SAND	155	172
AND FINE GRAVEL UP TO 1/2 MINUS		
W.L. NOW 30'		
BLUE CLAY	172	191

Work started JAN 28 1966 Completed FEB 11 1966  
Date well drilling machine moved off of well FEB 11 1966

(13) PUMP:

Manufacturer's Name BERKELEY  
Type: SUBMERSIBLE H.P. 10

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLIAM J. STENNETT  
(Person, firm or corporation) (Type or print)

Address 361 WARNER MILNE RD. OREGON CITY

Drilling Machine Operator's License No. 170

[Signed] William J. Stennett  
(Water Well Contractor)

Contractor's License No. 5 Date Feb 24 1966

PUMP SERVICE, SILVERTON ORE.