

NOTICE TO WATER WELL CONTRACTOR: The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

**RECEIVED**  
**WATER WELL REPORT**  
 MAR 21 1966  
 STATE OF OREGON  
 (Please type or print)

CLAC  
 17296

GR-723  
 3/2-8

State Well No. 3/2-8  
 State Permit No.

**(1) OWNER:**

Name RUDOLPH PAVLINAC  
 Address RT 1 Box 690  
OREGON CITY

**(2) LOCATION OF WELL:**

County CLACKAMAS (Driller's well number)  
 1/4 Section 8 T. 3S R. 2E W.M.  
 Bearing and distance from section or subdivision corner

**(3) TYPE OF WORK (check):**

Well  Deepening  Reconditioning  Abandon   
 andonment, describe material and procedure in Item 12.

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal  Irrigation  Test Well  Other   
 (5) TYPE OF WELL: Rotary  Driven  Cable  Jetted  Dug  Bored

**(6) CASING INSTALLED:**

Threaded  Welded   
 " Diam. from NONE ft. to ..... ft. Gage .....  
 ORIGINAL from CASING to ..... ft. Gage 25#  
8 " Diam. from 0 ft. to 400 ft. Gage .....

**(7) PERFORATIONS:**

Perforated?  Yes  No  
 Type of perforator used  
 Size of perforations in. by in.  
 ..... perforations from ..... ft. to ..... ft.  
 ..... perforations from ..... ft. to ..... ft.  
 ..... perforations from ..... ft. to ..... ft.  
 ..... perforations from ..... ft. to ..... ft.  
 ..... perforations from ..... ft. to ..... ft.

**(8) SCREENS:**

Well screen installed?  Yes  No  
 Manufacturer's Name ..... Model No. ....  
 Diam. Slot size Set from ..... ft. to ..... ft.  
 Diam. Slot size Set from ..... ft. to ..... ft.

**(9) CONSTRUCTION:**

Well seal—Material used in seal NONE ADDED  
 Depth of seal UNKNOWN ft. Was a packer used? N.O.  
 Diameter of well bore to bottom of seal UNKNOWN in.  
 Were any loose strata cemented off?  Yes  No Depth .....  
 Was a drive shoe used?  Yes  No  
 Was well gravel packed?  Yes  No Size of gravel: .....  
 Gravel placed from ..... ft. to ..... ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of water? ..... depth of strata .....  
 Method of sealing strata off .....

**(10) WATER LEVELS:**

Static level 236 ft. below land surface Date Feb 24/66  
 Artesian pressure lbs. per square inch Date .....

**(11) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom?  
 Yield: gal./min. with ft. drawdown after hrs.  
WELL MADE 200 GPM BEFORE WE REDRILLED " "  
 Bailor test NONE gal./min. with TRIED drawdown after hrs.  
 Artesian flow g.p.m. Date  
 Temperature of water 56 Was a chemical analysis made?  Yes  No

**(12) WELL LOG:**

Diameter of well below casing 8  
 Depth drilled 562 ft. Depth of completed well 400 ft.  
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
STICKY BLUE CLAY	400	415
SANDY BLUE CLAY	415	526
STICKY BLUE CLAY	526	535
BROWN FINE SAND	535	540
TRACE OF WATER		
STICKY BLUE CLAY	540	562
CAVING BADLY		
AS NO WATER WAS FOUND, WELL WAS NOT CASED, ANY MORE AND PUMP REINSTALLED		

Work started FEB 14 19 66 Completed FEB 18 19 66  
 Date well drilling machine moved off of well FEB 18 19 66

**(13) PUMP:**

Manufacturer's Name BERKELEY  
 Type: TURBINE H.P. 30

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLIAM J. STENNETT  
 (Person, firm or corporation) (Type or print)

Address 361 WARNER MILNER D. ORE CITY

Drilling Machine Operator's License No. 170

[Signed] William J. Stennett  
 (Water Well Contractor)

Contractor's License No. 5 Date Feb 24, 19 66