

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

RECEIVED
WATER WELL REPORT

CLACK
17386

STATE OF OREGON JUL 9 1973 State Well No. 35/2E-14 CC

STATE ENGINEER (Please type or print) STATE ENGINEER State Permit No.

SALEM OREGON 8-6339 (Do not write above this line)

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

(1) OWNER:

Name W. E. ALBEKE
Address 16107 SW WILSON ROAD
OREGON CITY ORE.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded 1/2" wall
8" Diam. from 0 ft. to 160 ft. Gage 7/8"
6" Diam. from 110 ft. to 300 ft. Gage 3/4"
" Diam. from " ft. to " ft. Gage "

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used TORCH
Size of perforations 1/4 in. by 24 in.
1.05 perforations from 210 ft. to 260 ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level.
Was a pump test made? Yes No If yes, by whom? OWNER
1. 50 gal./min. with 13' drawdown after 56 hrs.
" 70 " " " 56 "
" " " " " "
Bailer test 29 gal./min. with 25 ft. drawdown after 2 hrs.
Artesian flow _____ g.p.m.
Temperature of water 57 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used 41-EARLY 42 BAGS CEMENT
Well sealed from land surface to 6.5 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 42 sacks
Number of sacks of bentonite used in well seal 1 sacks
Brand name of bentonite QUICK GEL
Number of pounds of bentonite per 100 gallons _____
of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plug _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth _____ strata
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County CLACKAMAS Driller's well number _____
SW 1/4 SW 1/4 Section 14 T. 35 R. 2E W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 214 ft.
Static level 159 ft. below land surface. Date 6/9/73
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 8"
Depth drilled 300 ft. Depth of completed well 300 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOPSOIL	0	3	
YELLOW CLAY	3	57	
GREY AND BLUE CLAY	57	101	
A TOUGH GREY CLAYSTONE	101	160	
ALMOST BLUE SANDSTONE	160	214	
WATER BEARING AT 214 AT 18 GPM	214	140	
HARD SANDSTONE	214	234	
SOME CRUMBLY SANDSTONE W.B.	234	265	
NOW BALLS 29 GPM.		140	
STICK BLUE CLAY	265	300	
AFTER PUMPING STATIC WATER LEVEL 159'			

Work started MAY 11 1973 Completed MAY 26 1973
Date well drilling machine moved off of well JUNE 9 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] William J. Stennett Date June 13, 1973
(Drilling Machine Operator)
Drilling Machine Operator's License No. 170

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name WILLIAM J. STENNETT
(Person, firm or corporation) (Type or print)
Address 351 WARNER MILNE RD ORE CITY
[Signed] William J. Stennett
(Water Well Contractor)
Contractor's License No. 50 Date June 12, 1973