

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM 10, OREGON
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

State Well No. 3/2-25

State Permit No. _____

(1) OWNER:

Name NELS SMITH
Address 4519 SE JOHNSON CREEK BND
PORTLAND 6 ORE.

(2) LOCATION OF WELL:

County CLACKAMAS Driller's well number 4146
1/4 1/4 Section 25 T. 3S R. 2E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
a. Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:

Threaded ☐ Welded ☒ 250
6" Diam. from 0 ft. to 293 ft. Gage
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? ☒ Yes ☐ No
Type of perforator used TORCH
Size of perforations 3/8 in. by 4 in.
72 perforations from 280 ft. to 290 ft.
128 perforations from 200 ft. to 205 ft.
60 perforations from 180 ft. to 186 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed ☐ Yes ☒ No
Manufacturer's Name _____ Model No. _____
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT GROUT
Depth of seal 34 ft. Was a packer used? _____
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth _____
Was a drive shoe used? ☐ Yes ☒ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel: _____
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 106 ft. below land surface Date 3/21/63
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☒ No If yes, by whom? PUMP PIPE AND PUMP
Yield: 60 gal./min. with 146 ft. drawdown after 4 hrs.
" " " "
" " " "
Bailer test 20 gal./min. with ft. drawdown after 2 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled 293 ft. Depth of completed well 293 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	2
YELLOW CLAY AND GRAVEL	2	18
BLACK ROCK	18	189
GREY CLAY	189	227
GREEN CLAY	227	261
BROWN CLAY	261	279
CONGLOMERATE	279	288
BLUE CLAY	288	293

Work started 2/2 19 63 Completed 3/22 19 63
Date well drilling machine moved off of well 3/22 19 63

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R.J. STRASSER DRILLING CO.
(Person, firm or corporation) (Type or print)
Address 8110 SE SUNSET LANE PORT 6, ORE.

Drilling Machine Operator's License No. 190

[Signed] Robert L. Strasser
(Water Well Contractor)

Contractor's License No. 10 Date MAR 30, 1963