RECEIVED
APR 22 1959
STATE ENGINEER
SALEM, OREGON

CLAC 01864

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

01864

State Well No. 3/7-5F

State Permit No.

(1) OWNER:
Name Oregon Babtist Convention
Address 412 Fitzpatrick Bldg
Portland 5, Oregon

(2) LOCATION OF WELL:
County Clackamas Owner's number, if any—
¼ ¼ Section T. R. W.M.
Bearing and distance from section or subdivision corner
Center of N.W. 10 acres of S.E. 40 acres of the N.W. 1/4 of Section 5, TWN 3S, R7E, WM

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☐
48 In. Diam. from 0 ft. to 10 ft. Gage 5Inch
14 in. Diam. from 10 ft. to 12 ft. Gage 10
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☐ Yes ☒ No
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? ☒ Yes ☐ No To what depth? ft.
Material used in seal— Concrete
Did any strata contain unusable water? ☒ Yes ☐ No
Type of water? Surface Depth of strata 8 ft
Method of sealing strata off

(10) WATER LEVELS:
Static level 8 ft. below land surface Date 4/20/59
Artesian pressure lbs. per square inch Date

Log Accepted by:
[Signed] (Owner) Date 4/20/59, 19

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? owner
Yield: 20 gal./min. with 1 ft. drawdown after one hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 46 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG: Diameter of well 48 inches.
Depth drilled 14 ft. Depth of completed well 12 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Decomposed rock and earth	0	2 ft
Sand, Gravel, Bolders	2	14

Work started 2/15/59 19 . Completed 4/20/59 19

(13) PUMP:
Manufacturer's Name Fairbanks Morse
Type: Centrifugal H.P. 5

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Barker Drilling & Supply (Person, firm, or corporation) (Type or print)
Address 1708 N.E. Bell Dr.
Driller's well number 3 (Three)
[Signed] Charles N. Barker (Well Driller)
License No. 248 Date 4/20/59, 19

Manager, Camp Arrah Wanna (USE ADDITIONAL SHEETS IF NECESSARY)