

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON FEB 17 1976

State Well No.

(Please type or print)

(Do not write above this line)

WATER RESOURCES DEPT. Permit No.

SALEM, OREGON

CLAC 01881

RECEIVED

35/7E-9

(1) OWNER:

Name Paul Rice Address Box 234 Rhododendron, Ore.

(10) LOCATION OF WELL:

County CLATSOP Driller's well number 1/4 Section 9 T. 35 R. 7-E W.M. Bearing and distance from section or subdivision corner

(2) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Driven [] Cable [x] Jetted [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [x] Irrigation [] Test Well [] Other []

(5) CASING INSTALLED:

6" Diam. from 0 ft. to 127 ft. Gage 250

(6) PERFORATIONS:

Perforated? [x] Yes [] No. Type of perforator used Torch Size of perforations 60 in. by 9 in. perforations from 70 ft. to 127 ft.

(7) SCREENS:

Well screen installed? [] Yes [x] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [x] No If yes, by whom? Bailor test 36 gal./min. with 62 ft. drawdown after 3 hrs.

(9) CONSTRUCTION:

Well seal—Material used CEMENT GROUT Well sealed from land surface to 50 ft. Diameter of well bore to bottom of seal 10" in. Diameter of well bore below seal 10" x 8" to 75' Number of sacks of cement used in well seal 25 sacks

(11) WATER LEVEL: Completed well.

Depth at which water was first found 125 ft. Static level 53 ft. below land surface. Date 1/10/76 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6 Depth drilled 140 ft. Depth of completed well 140 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include: Boulders & CLAY (0-27, 0), ROCK GREY S.F.T (27-33, 0), CLAY GREY (33-55, 0), Boulders & CLAY yellow (55-74, 0), CLAY GREY (74-112, 0), ROCK GREY M.H. (74-125, 53), ROCK GREY SOFT W.B. (125-127, 53), ROCK GREY M.H. (127-140, 53)

RECEIVED

FEB 17 1976

WATER RESOURCES DEPT. SALEM, OREGON

Work started 12/3 1975 Completed 1/12 1976

Date well drilling machine moved off of well 1/15 1976

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Kevin N. Brant Date 2/1, 1976 (Drilling Machine Operator)

Drilling Machine Operator's License No. 246

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name LANZ WELL DRILLING (Person, firm or corporation) (Type or print)

Address 15702 S. Neilburg Rd Oregon City

[Signed] Donald L. Lanz (Water Well Contractor)

Contractor's License No. 565 Date 2-2, 1975