

(CLAC 18822)

25/3E/2

OFFICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days of the date
of well completion.

RECEIVED

WATER WELL REPORT

SEP 29 1993

STATE OF OREGON

State Well No.

(Please type or print)

(Do not write above this line)

State Permit No.

WATER RESOURCES DEPT.
SALEM, OREGON

1) OWNER:

Name: Angus Moore
Address: 17211 Box 375 Boxing, Oregon

(11) LOCATION OF WELL:

County: Clatsop Driller's well number
Section: 2-25 R. 3E W.M.
Bearing and distance from section or subdivision corner

2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

3) TYPE OF WELL:

Open Driven
Cased Jetted
Dig Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(12) WELL LOG:

Diameter of well below casing 10 inches
Depth drilled 175 feet Depth of completed well 175 feet
Formation: Describe color, texture, grain size and structure of materials
and show thickness and nature of each stratum and aquifer penetrated
with at least one entry for each change of formation. Report each change
in position of Static Water Level as drilling proceeds. Note drilling rates.

| | From | To | SWL |
|--------------------------------------|------|-----|-----|
| soil | 0 | 2 | |
| clay | 2 | 32 | |
| gravel | 32 | 130 | |
| sand stone with water bearing strata | 130 | 180 | |

CASING INSTALLED:

Threaded Welded
Diam. from 0 ft. to 175 ft. Gage 530
Diam. from _____ ft. to _____ ft. Gage _____
Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No
Type of perforator used: Touch cut
Size of perforations: 1/4 in. by 10 in.
12 perforations from 150 ft. to 175 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Type _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level: 127 ft. below land surface Date: July-67
Well pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No by whom? _____
Flow rate _____ gal./min. with _____ ft. drawdown after _____ hrs.
Ballor test: 30 gal./min. with 2 ft. drawdown after 2 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 53 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal Material used: Cement & sand
Depth of seal: 150 feet
Diameter of well bore to bottom of seal: 8 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: 20/40
Gravel placed from 130 ft. to 175 ft.

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] C. W. Olsen Date: July 24 1967
(Drilling Machine Operator)

Drilling Machine Operator's License No. 214

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME: C. W. Olsen (Type or print)
(Person, firm or corporation)

Address: 17211 S.E. Powell Fresh

[Signed] C. W. Olsen (Water Well Contractor)

Contractor's License No. 202 Date: July 24 1967

(USE ADDITIONAL SHEETS IF NECESSARY)