CLAC 1894

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED MAY 14 1964 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

CLAC 01894

State Well No. 3/7-9

State Permit No.

(1) OWNER:
Name McLANE, George H.
Address Wemme, Oregon 97067
(Twin Cedars, Welches Rd)

(2) LOCATION OF WELL:
County Clackamas Driller's well number 13-1964
¼ ¼ Section 9 T. 3S R. 7E W.M.
Bearing and distance from section or subdivision corner
Lot 18-1 Road 1440

(3) TYPE OF WORK (check):
Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:
Threaded ☐ Welded ☐
6" Diam. from 0 ft. to 58 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? ☐ Yes ☒ No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Bentonite
Depth of seal 30 ft. Was a packer used? No
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 40 ft. below land surface Date May 6, '64
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 30 gal./min. with 3 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☒ Yes ☐ No

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 58 ft. Depth of completed well 58 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Topsoil	0	5
Brown Sandy clay	5	15
Clay & Boulders	15	30
Medium brown Sand	30	50
Brown Sandy clay	50	52
Medium brown Sand	52	58

Work started April 20 19 . Completed May 6 1964
Date well drilling machine moved off of well May 6 1964

(13) PUMP:
Manufacturer's Name Fairbanks-Morse
Type: Submersible H.P. 3/4

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME SKYKES DRILLING & SUPPLY
19215 (Person, firm or corporation) (Type or print)
Address S. E. McLoughlin Blvd. Gladstone, Ore.
Drilling Machine Operator's License No. 234
[Signed] George H. Skyles (Water Well Contractor)
Contractor's License No. 58 Date 5-12, 1964

(USE ADDITIONAL SHEETS IF NECESSARY)