WATER WELL REPORT STATE OF OREGON

APR 20 1981

WATER RESOURCES DEPT
SALEM, OREGON

State Well No.

35/28-136

(1) OWNER:	(10) LOCATION OF WELL:		
Name U.S. DEPARTMENT OF AGRICULTURE	County Clackamas Driller's well number 8(a)-81-7		
Address 19559 S.E. Division St.	4 NW 4 Section 13 T. 3 S	R 7 E	W.M.
City Gresham State Ore 97030	Tax Lot # Lot Blk	Subdivisio	n
(2) TYPE OF WORK (check):	Address at well location: ZIGZAG RANGER STATION MT. HOOD NATIONAL FOREST, TOLLGATE CAMPGROUND		
New Well $oldsymbol{\square}$ Deepening \Box Reconditioning \Box Abandon \Box			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 38		ft.
		and surface. Date	
Rotary Air Driven Domestic X Industrial Municipal Rotary Mud Dug Irrigation Test Well Other	Artesian pressure lbs. pe	r square inch. Dat	<u>e</u>
Mithdrawal Reinjection	(12) WELL LOG: Diameter of well below casing		
CASING INSTALLED: Steel Plastic	Depth drilled 72 ft. Depth of c	completed well	72 ft.
Threaded □ Welded ☑6" Diam. from+1 ft. to72 ft. Gauge280	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level		
	and indicate principal water-bearing strata.		
LINER INSTALLED:	MATERIAL	From To	SWL
"Diam. from	BROWN SAND GRAY WITH COBBLES	0 3	
	BROWN SAND COBBLES & BOULDERS	3 10	
(6) PERFORATIONS: Perforated? ☐ Yes 反 No Type of perforator used	COBBLES GRAY SAND	10 19	
Size of perforations in. by in.	SOFT SANDSTONE PACKED SAND	19 21	
	GRAY SAND	21 36	
perforations from	GRAY SAND & BOULDERS	36 42	18
perforations from	HEAVING GRAY SAND	42 57	
perforations from ft. to ft.	BROWN SAND & CHARRED WOOD	57 63	6
(7) SCREENS: Well screen installed?	GRAY SAND VERY FINE GRAVEL.	63	
Manufacturer's Name JOHNSON WELL SCREEN	HEAVING	66	2
Type TELESCOPING Model No.	COARSE GRAY SAND SMALL GRAVEL	66 71	2_
Diam6." Slot Size30 Set from6.8 ft. to72 ft.	TIGHT SAND & GRAVEL	71 72	3
Diam. Slot Size Set from ft. to ft.			
(8) WELL TESTS: Drawdown is amount water level is lowered below static level			_
Was a pump test made? Z Yes No If yes, by whom? driller			
d: 30 gal/min. with 27 ft. drawdown after 8 hrs.			
Air test gal./min. with drill stem at ft. hrs.			
Bailer test gal./min. with ft. drawdown after hrs.			
tesian flow g.p.m.			
perature of water 52 Depth artesian flow encountered ft.	Work started 3-3 19 81 Complete	ed 4-3	1981
(9) CONSTRUCTION: Special standards: Yes 🛣 No □	Date well drilling machine moved off of well 4-6 1981		
Well seal—Material used CEMENT & BENTONITE	Drilling Machine Operator's Certification:		
Well sealed from land surface to	This well was constructed under my direct so	upervision. Mat	erials used
Diameter of well bore to bottom of seal10 in.	and information reported above are true to my best knowledge and helief.		
Diameter of well bore below seal	[Signed] Date 1, 19.0.		
Number of sacks of cement used in well seal 3ydsconcrete&3 sacks	Drilling Machine Operator's License No. 92	_4	
How was cement grout placed? bentoni			
BENTONITE PUMPED 8' - 17'	Water Well Contractor's Certification:		
CEMENT 0' - 8'	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Was pump installed?	Name FLORES DRILLING & PUMP COMPANY		
Was a drive shoe used? ♀ Yes □ No Plugs Size: location ft. Did any strata contain unusable water? □ Yes □ No	(Person, firm or corporation) (Type or print) 121/2 PIVED DD N F CERVATS ORE 97026		
Type of Water? depth of strata	Address 12143 RIVER RD.N.E.GERVAIS, ORE 97026		
Method of sealing strata off	[Signed] Thomas O Tolack		
Was well gravel packed? ☐ Yes 🕏 No Size of gravel:	(Water Well Contractor)		
Gravel placed from	Contractor's License No. 590 Date 4-15 ,1981		
IV.			