## WATER WELL REPORT STATE OF OREGON

CLAC 01926

## REGEIVED NOV 12 1981 WATER RESOURCEState Perpit No.

SALEM, CRECON

(1) OWNER:	(10) LOCATION OF WELL:
Name Golden Poles Chalet Association	County Clackamas Driller's well number 3281
Address P.O. Box 383	4 4 Section 23 T. 3S R. 8 E W.M.
City Government Camp State OR 97028	Tax Lot # Lot Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location: Government Camp, Oregon
New Well ⊠ Deepening □ Reconditioning □ Abandon □	(11) MARIED FRANCE C. 1.1. II
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 14 ft.
	Static level 6 ft. below land surface. Date 10-3-8
Rotary Air 🗱 Driven 🗌 Domestic 🗎 Industrial 🗎 Municipal 🗍	Artesian pressure lbs. per square inch. Date
Ca □ Bored □ Thermal: Withdrawal □ Reinjection □	(12) WELL LOG: Diameter of well below casing
(5) CASING INSTALLED: Steel X Plastic Threaded Welded	Formation: Describe color, texture, grain size and structure of materials; and show
8 "Diam from 0 ft to 100 ft Gauge .25	thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
	Sand, gravel & boulders
	(dirty) 0 14
(6) PERFORATIONS: Perforated? X Yes \( \text{No} \)  Type of perforator used ROtary	Sand, gravel & boulders
Size of perforations $1/8$ in by $1\frac{1}{2}$ in.	(clean) 14 20 3
350 perforations from 81 ft. to 99 ft.	
perforations from	Sand, gravel & boulders 20 62
perforations from	
	Sand, gravel & boulders
(7) SCREENS: Well screen installed?   Wes XNo  Manufacturer's Name	(water bearing) 62 100 6
Type	
Diam. Slot Size Set from ft. to ft.	
Diam. Slot Size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
a pump test made?   Yes  No If yes, by whom?	
Yield: gal./min. with ft. drawdown after hrs.	
11 " " "	
Air test 400 gal/min, with drill stem at 95 ft. 2 hrs.	
Bailer test gal/min. with ft. drawdown after hrs.	
sian flow g.p.m.	
Temperature of water Depth artesian flow encountered ft.	Work started 9-28 1981 Completed 10-3 1981
(9) CONSTRUCTION: Special standards: Yes \( \text{No } \text{M} \)	Date well drilling machine moved off of well 10-3 19 81
Wellseal—Material used cement w/ 5% bentonite	Drilling Machine Operator's Certification:
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
Diameter of well bore below seal	(Drilling Machine Operator)
How was cement grout placed? pump.d	Drilling Machine Operator's License No. 224
now was cement grout placed:	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is true to
Was pump installed?	the best of my knowledge and belief.
Was a drive shoe used?   Yes □ No Plugg Size: locationft.	Name Skyles Drilling, Inc.  (Person, firm or corporation) (Type or print)
Did any strata contain unusable water?	Address 1169 Molalla Ave Oregon City. OR
Type of Water? depth of strata	[Signed] Marine De Shalle
Method of sealing strata off	(Water Well Contrag or)
Was well gravel packed? ☐ Yes XNo Size of gravel:	Contractor's License No. 553 Date 10-9, 1981
t -ruyer macest from	· ·