

STATE OF OREGON
WATER WELL REPORT
 (as required by ORS 537.765)

RECEIVED

APR 5 1985
 PLEASE TYPE or PRINT IN INK

CLAC

01943

45/1W-12cc
 Leonard

(for official use only)

(1) OWNER: SALEM, OREGON

Name WEYERHAEUSER CO
 Address PO BOX 235
 City AURORA State Oregon

(2) TYPE OF WORK (check): Reconditioning
 New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: Rotary Air Cable Rig Driven
 Rotary Mud Dug
 Cable Bored

(4) PROPOSED USE (check): Domestic Industrial Municipal
 Thermal Withdrawal ReInjection
 Other: GRAVEL FEED WELLS Test
 Piezometric Grounding

(5) CASING INSTALLED: Steel Plastic
 Threaded Welded
 5" Diam. from 0 ft. to 240 ft. Gauge CLASS 160
 " Diam. from " ft. to " ft. Gauge

LINER INSTALLED: Steel Plastic
 Threaded Welded
 " Diam. from " ft. to " ft. Gauge

(6) PERFORATIONS: Perforated? Yes No
 Size of perforations in. by in.
 perforations from " ft. to " ft.
 perforations from " ft. to " ft.
 perforations from " ft. to " ft.

(7) SCREENS: Well screen installed? Yes No
 Manufacturer's Name
 Type Model No.
 Diam. Slot Size Set from " ft. to " ft.
 Diam. Slot Size Set from " ft. to " ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 gal./min. with " ft. drawdown after " hrs.
 Air test gal./min. with drill stem at " ft. hrs.
 Bailer test gal./min. with " ft. drawdown after " hrs.
 Artesian flow g.p.m.
 Temperature of water Depth artesian flow encountered " ft.

(9) CONSTRUCTION: Special standards: Yes No
 Well seal—Material used BENTONITE
 Well sealed from land surface to 25 ft.
 Diameter of well bore to bottom of seal 10 in.
 Diameter of well bore below seal 6 in.
 Amount of sealing material 6E sacks pounds
 How was cement grout placed? Granular Bentonite

Was pump installed? Yes No Type Turbine HP 100 Depth 240 ft.
 Was a drive shoe used? Yes No Plugs Size: location ft.
 Did any strata contain unusable water? Yes No
 Type of Water? depth of strata ft.
 Method of sealing strata off
 Was well gravel packed? Yes No Size of gravel: 1/4 MITHUS
 Gravel placed from 240 ft. to 273 ft.

(10) LOCATION OF WELL by legal description:
 County CLACKAMAS SW 1/4 SW 1/4 of Section 12 of
 Township 45, Range 1W, WM.
 (Township is North or South) (Range is East or West)
 Tax Lot Lot Block Subdivision
 MAILING ADDRESS OF WELL (or nearest address)
SAME

(11) WATER LEVEL of COMPLETED WELL:
 Depth at which water was first found 86 ft.
 Static level 65 ft. below land surface. Date Mar 11, 1985
 Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing Larger 6 in.
 Depth drilled 290 ft. Depth of completed well N/A ft.
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SILT BROWN	1	86	
CEMENT GRAVEL	86	118	
CLAY GREY	118	142	
CLAY TAN	142	150	
CLAY GREEN	150	163	
SAND CLAY LAYERS	163	196	
CLAY GREEN	196	208	
SAND	208	212	
CLAY BLUE GREY	212	244	
CLAY LT BLUE	244	264	
SAND SILTY GREY	264	278	
SAND WOOD GRAVEL	278	280	
SILT SAND LAYERS	280	293	

ADDITIONAL INFORMATION ON BACK

note: Depth measured from top of well (ie, 1' above ground level)
 Date work started Feb 06 85 /completed Mar 11 85
 Date well drilling machine moved off of well Mar 14 1985

(unbonded) Water Well Constructor Certification (if applicable):
 This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
 [Signed] _____ Date _____, 19 _____

(bonded) Water Well Constructor Certification:
 Bond 5834200 Issued by: Thomas Haun
 (number) (Surety Company Name)
 On behalf of BECK WELL DRILLING
 (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
 (Signed) Richard Beck
 (Water Well Constructor)
 (Dated) Mar 24, 1985

NOTICE TO WATER WELL CONSTRUCTOR
 The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
 SALEM, OREGON 97310
 within 30 days from the date of well completion.

SP*46866-690