

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

CLAC
01979

STATE OF OREGON
(Please type or print)

(Do not write above this line)

State Well No. 15/1W-360
State Permit No. _____

(1) OWNER:

Name Jim Seymore
Address Rt. 1 Box 107
Hubbard, Or. 97032

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Dug
Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 140 ft. Gage .250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____

Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? driller
Yield: 20 gal./min. with 11 ft. drawdown after 3 hrs.

Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m.

Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 24 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 13 sacks
How was cement grout placed? Pressure grouted from 24 ft. to land surface.

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.

Did any strata contain unusable water? Yes No

Type of water? _____ depth of strata _____

Method of sealing strata off _____

Was well gravel packed? Yes No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Clackamas Driller's well number 123
SW $\frac{1}{4}$ SW $\frac{1}{4}$ Section 36 T.4S R.1W W.M.

Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 140 ft.

Static level 74 ft. below land surface. Date 7-26-79

Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 150 ft. Depth of completed well 150 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top soil	0	2	
Clay, brown	2	18	
Clay, blue	18	78	
Clay, sand, blue, black	78	88	
Sand, black, fine	88	97	
Sand, gravel, black, med.	97	104	
Sand, clay, black, fine, bl.	104	140	
* Sandstone, soft, fract.	140	150	

RECEIVED

JUL 31 1979

WATER RESOURCES DEPT
SALEM, OREGON

Work started 7-25 1979 Completed 7-26 1979

Date well drilling machine moved off of well 7-26 79

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] George J. Wainwright Date 7-27, 1979
Drilling Machine Operator

Drilling Machine Operator's License No. 837

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name B & G Drilling
(Person, firm or corporation) (Type or print)

Address 10030 S. Macksburg Rd. Canby, Or.

[Signed] George J. Wainwright
(Water Well Contractor)

Contractor's License No. 637 Date 7-27, 1979