

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON

within 30 days from the date of well completion

RECEIVED
 STATE OF OREGON
 STATE ENGINEER
 SALEM, OREGON

MAR - 9 1971

(Please type or print)

(Do not write above this line)

CLAC
 02020

State Well No.

5/1W-1

State Permit No.

(1) OWNER:

Name Jack R. Bigej
 Address Rt. 1 Box 245, Hubbard, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded

6" Diam. from 0 ft. to 89 ft. Gage 250
 5" Diam. from 86 ft. to 135 ft. Gage 10

PERFORATIONS:

Perforated? Yes No

Type of perforator used Cutting torch
 Size of perforations 1/8 in. by 12 in.
 68 perforations from 100 ft. to 135 ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
 Type Model No.
 Diam. Slot size Set from ft. to ft.
 Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
 Yield: gal./min. with ft. drawdown after hrs.
 " " " "
 " " " "
 Bailer test 55 gal./min. with 15 ft. drawdown after 2 hrs.
 Artesian flow g.p.m.
 Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Bentonite & Puddled Clay
 Well sealed from land surface to 22 ft.
 Diameter of well bore to bottom of seal 10 in.
 Diameter of well bore below seal 6 in.
 Number of sacks of cement used in well seal sacks
 Number of sacks of bentonite used in well seal 2 sacks
 Brand name of bentonite National
 Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
 Was a drive shoe used? Yes No Plugs Size: location ft.
 Did any strata contain unusable water? Yes No
 Type of water? depth of strata
 Method of sealing strata off
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County CLATSOP Driller's well number 71-7
 1/4 1/4 Section 1 T. 5S R. 1W W.M.
 Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 22 ft.
 Static level ft. below land surface. Date
 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 135 ft. Depth of completed well 135 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil-Brown	0	3	
Clay-Brown-Sandy	3	22	
Clay-Blue	22	24	
Sand-Br.-Clay-Br.-Water trace	24	86	
Sand-Br.-Clay-Br.-Water trace	86	87	
Clay-Br.-Sand streaks-Water seep	87	96	
Clay-Blue-Sandstone-Black	96	120	
Sandstone-Black-Soft-Water bearing	120	135	

Work started 2-26 19 71 Completed 3-1 19 71
 Date well drilling machine moved off of well 3-2 19 71

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Bennett Skinner Date 3-5, 1971
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 277 5240

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name S. & M. Drilling & Supply
 (Person, firm or corporation) (Type or print)

Address Rt. 1 Box 31, Canby, Oregon 97013

[Signed] Bennett Skinner
 (Water Well Contractor)

Contractor's License No. 520 Date 3-5, 19 71