

RECEIVED

JUN 21 1968

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

STATE ENGINEER SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON (Please type or print)

CLAC 02029

State Well No. 5/1w-1 G

G-4497

State Permit No.

(1) OWNER: Vladimir KOSTRIKIN

Name Walter Kostrikin
Address Rt 1 Box 219A Hubbard Ore.

(2) LOCATION OF WELL:

County Clackamas Driller's well number
SW 1/4 NE 1/4 Section 1 T. 5 S R. 1 W W.M.

Bearing and distance from section or subdivision corner
It is 135 FT West and 2.5 FT North of the Intersection of the Farmers Drive way with the Maridian Rd South of Whiskey Hill School

(3) TYPE OF WORK (check):

Well [checked] Deepening [] Reconditioning [] Abandon []

(4) PROPOSED USE (check):

Domestic [checked] Industrial [] Municipal [] Rotary [] Driven []
Irrigation [checked] Test Well [] Other [] Cable [checked] Jetted []
Dug [] Bored []

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded [] Welded []
6" Diam. from 0 ft. to 14.5 ft. Gage 250

(7) PERFORATIONS:

Perforated? [checked] Yes [] No
Type of perforator used Star
Size of perforations 1 1/2 in. by 3/8 in.
300 perforations from 13.1 ft. to 14.1 ft.

(8) SCREENS:

Well screen installed? [] Yes [checked] No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Gravel
Depth of seal 4.5 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? [] Yes [checked] No
Was a drive shoe used? [checked] Yes [] No
Was well gravel packed? [] Yes [checked] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [checked] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 60 ft. below land surface Date 6-14-68
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [] No If yes, by whom? Driller
Yield: 150 gal./min. with 54 ft. drawdown after 11 hrs.

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well below casing None

Depth drilled 145 ft. Depth of completed well 145 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Topsoil Brown clay, Brown silt, Blue clay, Cement gravel (Blue), Cement gravel (Brown), Sand (Brown), Dark Brown clay, Black clay, Dark silt, Black clay & silt, Dark sand (fine), Sand & gravel, Gray clay.

Work started 6-7 1968 Completed 6-14 1968
Date well drilling machine moved off of well 6-14 1968

(13) PUMP:

Manufacturer's Name Gould
Type: Sella H.P. 10

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John W Beck well driller
(Person, firm or corporation) (Type or print)

Address 954 SIVY st Canby Ore

Drilling Machine Operator's License No. 437

[Signed] John W Beck (Water Well Contractor)

Contractor's License No. 1149 Date 6-15 1968