

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. 55/1E/96c

State Permit No. Pg 1 of 2

WATER RESOURCES DEPT.
SALEM, OREGON

(1) OWNER:

Name Bill Rose
Address Rt1 Woodburn, Oreg

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
" Diam. from 0 ft. to 40 ft. Gage 250
12 " Diam. from 0 ft. to 325 ft. Gage 250
" Diam. from 100 to screen ft. Gage

(6) PERFORATIONS:

Perforated? Yes No
Type of perforator used Torch
Size of perforations 3/16 in. by 6 in. 3
190 perforations from 85 ft. to 325 ft.
between screens ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name Johanson
Type Irrigator Model No. 100
Diam. 12 Slot size 100 Set from 75 ft. to 85 ft.
Diam. 12 Slot size 100 Set from 140 ft. to 160 ft.

(8) WATER LEVEL:

Completed well 210 to 230
Static level 30 ft. below land surface Date 2505/28
Well pressure ft. lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
Flow: 250 gal./min. with 46 ft. drawdown after 5 hrs.
450 " " 54 " " 5 "
550 " " 64 " " 5 "
Packer test 650 gal./min. with 75 ft. drawdown after 5 hrs.
Artesian flow 875 g.p.m. Date

Temperature of water _____ Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Cement
Depth of seal 40 ft.
Diameter of well bore to bottom of seal 30 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Were any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel 3/8-1/4
Gravel placed from 0 ft. to 325 ft.

(11) LOCATION OF WELL:

County Clatsop Driller's well number _____
Section T. R. W.M.

Bearing and distance from section or subdivision corner
1375' S. & 70' E. of N.W. cor sec 9
T.5.S. -- R.1.E. S.W. 1/4 N.W. 1/4
8" to 350

(12) WELL LOG:

Diameter of well below casing 22" to 325
Depth drilled 256 ft. Depth of completed well 325 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

| MATERIAL | From | To | SWL |
|--|------|-----|-------|
| Top soil brn. | 0 | 2 | |
| Clay brn | 2 | 24 | |
| Fine sand brn. | 24 | 31 | |
| Clay grey | 31 | 44 | |
| Fine sand grey W.B. | 44 | 48 | |
| Clay grey | 48 | 51 | |
| Med sand & gravel brn. W.B. | 51 | 53 | |
| Clay brn. | 53 | 71 | |
| Med sand brn. W.B. | 71 | 78 | |
| Med sand & gravel brn. W.B. | 78 | 85 | |
| Clay brn. | 85 | 96 | |
| Clay grey | 96 | 136 | |
| Clay sandy grey | 136 | 142 | |
| Course sand blk. W.B. | 142 | 158 | |
| Clay grey hard | 158 | 191 | |
| Clay sandy grey | 191 | 202 | |
| Clay grey hard | 202 | 216 | |
| Course sand W.B. grey | 216 | 227 | |
| Clay sandy grey | 227 | 240 | |
| Med sand grey W.B. | 240 | 244 | |
| Clay grey gritty | 244 | 275 | |
| Packed sand grey W.B. | 275 | 293 | Cont. |
| Work started <u>4/20</u> 19 <u>70</u> Completed <u>5/28</u> 19 <u>70</u> | | | |
| Date well drilling machine moved off of well <u>5/26</u> 19 <u>70</u> | | | |

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

(Signed) C. F. Stadelic Date 5/25 1970
(Drilling Machine Operator)

Drilling Machine Operator's License No. 84

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Sadon & Sons (Type or print)

Address Silverton, Oreg

(Signed) Paul R. Stadelic
(Water Well Contractor)

Contractor's License No. 296 Date 5/25 1970

