NOTICE TO WATER WELL CONFRACTOR The original and first copy of this report are to be

8 1959 WATER WELL REPORT

STATE OF OREGON
STATE ENGINEER, SALEM DERICON OF STATE OF OREGON
(Please type or print)
within 30 days from the date Cold of Well completion.

(Do not write above this line)

CLAC State	Well No. 5/1W-12cc
W2000	
State	Permit No.
34990	

	<u> </u>			
(1) OWNER:	(11) LOCATION OF WELL:			
Name Lowell I HALL	County MANAGEN Driller's well n	umber	/	
Address R+ 1 BOX 190 Hubbarch, ORE	14 14 Section 72 T. 55 R. /W W.M.			
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision	n corner		
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐				
If abandonment, describe material and procedure in Item 12.				
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well below casing			
Cable 😿 Jetted 🗌 Domestic 🗆 Industrial 🗆 Municipal 🗎	Depth drilled /30 ft. Depth of comp			ft.
Dug ☐ Bored ☐ Irrigation 🔀 Test Well ☐ Other ☐	Formation: Describe color, texture, grain size			naterials
CASING INSTALLED: Threaded Welded W	and show thickness and nature of each strati	um and a	quifer pe	netrated,
18 " Diam. from + 1 tt. to 130 tt. Gage 250	with at least one entry for each change of form in position of Static Water Level as drilling pr			
	MATERIAL	From	то	SWL
		 	 	
	TOP SOIL	0	.3	
PERFORATIONS: Perforated? Yes No.	BROWN CLAY	3	40	
The of perforator used MILLS DERTORATOR	BROWN SAND	40	45	
Size of perforations 3/9 in. by 2 in.	BLUECLAY	45	65	
1.84 perforations from 1/2 tt. to 128 tt.	BLUE CLAY	100	75	
perforations from ft. to ft.	BROWN CLAY	90	90	
perforations from ft. to ft.	GRAVEL	111	116	
perforations from ft. to ft.	BLACK SAND	116	118	
perforations from ft. to ft.	GRAY SAND + GRAVEL	118	130	
(F) COMPANY	SANG SANGE	110	130	
(7) SCREENS: Well screen installed? ☐ Yes ☑ No		1		
Manufacturer's Name				
Type Model No.				
Diam. Slot size Set from ft. to ft.				
Diam. Slot size Set from ft. to ft.				
(8) WATER LEVEL: Completed well.		<u> </u>		
Static level 30 ft. below land surface Date 7-/-69		 		
esian pressure lbs. per square inch Date				
(9) WELL TESTS: Drawdown is amount water level is lowered below static level				
Was a pump test made? N Yes □ No If yes, by whom? Ste#LER				
ield: 110 gal./min. with 70. ft. drawdown after 70 hrs.	Work started JUNE 19 1969 Comple	ted QUN	EZI	19 69
280 " 84 " 30"	Date well drilling machine moved off of well	JUNE .	21	1969
" " "	Drilling Machine Operator's Certification:			
Bailer test gal./min. with ft. drawdown after hrs.	This well was constructed under my d			
Artesian flow g.p.m. Date	rials used and information reported abo knowledge and balief.	ve are i	irue io i	ny best
Temperature of water 540 Was a chemical analysis made? ☐ Yes 🕅 No		Date	7-2-6	, 1969
(10) CONSTRUCTION:	(Drilling Machine Operator)	. 4		
(10) CONSTRUCTION: Well seal—Material used Pudalle clay	Drilling Machine Operator's License No.	17	9	
Well seal—Material used PLOCLUG CLHY Depth of seal 35 ft.	Water Well Contractor's Certification:			
Diameter of well bore to bottom of seal	This well was drilled under my jurisdiction and this report is			
Were any loose strata cemented off? Yes No Depth	true to the best of my knowledge and beli	ef.	n.	CPOLU 13
Was a drive shoe used? X Yes \(\sigma \) No	NAME WILLIAM D. Chris	TENS	on J	<u> </u>
Did any strata contain unusable water? Yes You	(Person, firm or corporation)	Typ	pe or print)	_
	Address P. O. Box 343 A	wbba	red,	ORE
Type of water? depth of strata	11/11 200 7	1	N .	
Method of sealing strata off	[Signed] (Llean) Kristeria	1246	# <	•••••
Was well gravel packed? Tyes No Size of gravel:	(Water Well Contra		J	, n
Gravel placed from ft. to ft.	Contractor's License No. 5// Date	.Z-2-	69.,	19.6.7