

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

RECEIVED

STATE OF OREGON

State Well No.

55/W-13

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

CLAC
02101

(Please type or print)

MAY 14 1973

(Do not write above this line)

STATE ENGINEER

State Permit No.

SALEM, OREGON

G-6156

(1) OWNER:

Name Kamis Savin Kamis
Address Box 137 Bethlehem St. Woodburn, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

(4) PROPOSED USE (check):

Rotary Cable Driven Jetted Bored Domestic Industrial Municipal Irrigation Test Well Other

(5) CASING INSTALLED:

8" Diam. from 0 ft. to 140 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used Mills Knife
Size of perforations 3/8 in. by 3 1/4 in.
48 perforations from 130 ft. to 138 ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Driller
: 150 gal./min. with 20 ft. drawdown after 3 hrs.
" " " " "
" " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 30 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 2 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Clackamas Driller's well number
1/4 1/4 Section 13 T. 5s R. 1w W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 120 ft.
Static level 33 ft. below land surface. Date 5-9-73
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8
Depth drilled 140 ft. Depth of completed well 140 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top soil	0	2	
Clay sandy brown	2	32	
Clay blue	32	44	
Clay sandy brown	44	65	
Clay sandy gray	65	120	
Gravel sandy black	120	123	
Gravel and sand	123	128	
Sand silty	128	130	
Gravel and sand	130	131	
Sand coarse	131	134	
Gravel and sand	134	138	
Clay gray	138	140	

Work started 5-1 19 73 Completed 5-9 19 73
Date well drilling machine moved off of well 5-9 19 73

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] W. A. Blum Date 5-9, 19 73
(Drilling Machine Operator)

Drilling Machine Operator's License No. 395

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name William D. Christenson Jr.
(Person, firm or corporation) (Type or print)

Address P.O. Box 343 Hubbard, Oregon

[Signed] William D. Christenson Jr.
(Water Well Contractor)

Contractor's License No. 511 Date 5-9-73, 19.....