

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

Do not write above this line)

WATER RESOURCES DEPT
SALEM, OREGON

CLAC
02122

State Well No.

55/1w-14ab

State Permit No.

(1) OWNER:

Name LYKA CAM
Address Rt 2, Box 157 B.C., Woodburn, Or.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

(4) PROPOSED USE (check):

Rotary Driven Domestic Industrial Municipal
Jetted Bored Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded

8" Diam. from ±1 ft. to 165 ft. Gage ASO
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used M. 115 Knife
Size of perforations 3/16 in. by 3 in.
376 perforations from ft. to ft.
230 perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

..... a pump test made? Yes No If yes, by whom? Driller
Yield: 75+ gal./min. with 30 ft. drawdown after 16 hrs.
" " " " " "
" " " " " "
Peller test 40 gal./min. with 3 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered

(9) CONSTRUCTION:

Well seal—Material used Cement grout
Well sealed from land surface to 22 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 10 sacks
How was cement grout placed? gravity flow
.....
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County CLATSOP Driller's well number
NW 1/4 NE 1/4 Section 14 T. 55 R. 1W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 26 ft.
Static level 45 ft. below land surface. Date 10-24
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8

Depth drilled 171 ft. Depth of completed well 147 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|---------------------|------|-----|-----|
| Topsoil, Clayey | 0 | 16 | |
| CLAY, BRN, SANDY | 16 | 21 | |
| SAND, CLAYEY, SILTY | 21 | 42 | |
| CLAY, GRAY | 42 | 69 | |
| GRAVEL, SAND, CLEAN | 69 | 72 | 45" |
| GRAVEL SAND, SILTY | 72 | 88 | |
| SAND, GRAVEL, MED. | 88 | 93 | 45 |
| GRAVEL SAND, SILTY | 93 | 157 | |
| SAND, BK, FINE | 157 | 159 | 45 |
| CLAY, GRDY, | 159 | 171 | |

Work started 10-3-1980 Completed 10-23-1980
Date well drilling machine moved off of well 10-24-1980

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] H.E. Richardson Date 10-24, 1980
(Drilling Machine Operator)

Drilling Machine Operator's License No. 738

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Richardson Well Drilling
(Person, firm or corporation) (Type or print)

Address 5382 Sunnyview Rd N.E.

[Signed] Gene E. Richardson
(Water Well Contractor)

Contractor's License No. 650 Date 10-24-1980