

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED
MAR 18 1969

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

STATE OF OREGON
(Please type or print)
(Do not write above this line)

CLAC
02140

State Well No. 5/W-14
State Permit No. _____

G-7269 (#2)

(1) OWNER:

Name Vern C. Johnson
Address Rt. 2 Box 117, Woodburn, Oregon 97071

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
10" Diam. from top ft. to 160 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used Mills
Size of perforations 2 in. by 3/8 in.
420 perforations from 110 ft. to 140 ft.
170 perforations from 75 ft. to 87 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 55 ft. below land surface Date 3-13-69
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Driller
Field: 350 gal./min. with 30 ft. drawdown after 10 hrs.
250 " " 20 " " 10 "
200 " " 15 " " 10 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Drill cuttings Puddle Clay
Depth of seal 20 ft.
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Clackamas Driller's well number 1373
1/4 Section 14 T. 5S R. 1W W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 10"

Depth drilled 200 ft. Depth of completed well 160 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top Soil	0	3	
Yellow Clay	3	30	
Blue Shale	30	40	
Blue Shale little sandy grit	40	50	
Brown Gritty Shale	50	73	
Brown sand & fine Gravel	73	80	
Dark Brown Sand & Tight Gravel	80	87	
Brown Shale	87	110	
Gray sand and Gravel	110	123	
Brown sand & gravel	123	139	
Blue Shale	139	200	55

uncased from 160' to 200'

Work started 2-17-69 19 Completed 3-13-69 19

Date well drilling machine moved off of well 3-14-69 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] James Mars Date 3-14-69, 19____
(Drilling Machine Operator)

Drilling Machine Operator's License No. 74

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING COMPANY
(Person, firm or corporation) (Type or print)

Address 7641 35th Ave. NE (Rt. 2) Salem, Oregon

[Signed] Emil O. Beeber
(Water Well Contractor)

Contractor's License No. 2 Date 3-14-69, 19____