NOTICE TO WATER WELL CONTRACTOR The original and first copy	LL REPORT CEIVED -for the IIIIa	> Rights	Ja	a 56
of this report are to be filed with the STATE OF OREGONN AV2 1 1973 state Well No. 5511W-14				
STATE FNCINFER SALEM OPECON 07/10				
within 30 days from the date	bove this line)	To	•	
of well completion. 02147 (Do not write a)	SALEM, OREGON 67	ns?	3	
Cardin 16th		101		
(1) OWNER:	(10) LOCATION OF WELL:			
Name Pemetre Chachin	County Clacka mag Driller's well number			
Address RL Box 57-	NW 1/4 NW 1/4 Section 14 T. 53 R 1 W . W.M.			
Woodfurn ()	Bearing and distance from section or subdivision corner			
(2) TYPE OF WORK (check):				
New Well 🗸 Deepening 🗌 Reconditioning 🗌 Abandon 🗌	-			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.			
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 87 ft.			
Rotary Driven D Domestic M Industrial Municipal	Static level 30 ft. below land surface. Date $10/24/73$			
Cable Dug Jetted Dug Dered Irrigation Test Well Other	////·			
	Artesian pressure lbs. per squa:	ce inch.	Date	
CASING INSTALLED: Threaded D Welded	(12) WELL LOG: Diameter of well below casing			
ft. to ft. Gage				
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size and show thickness and nature of each stratu			
PERFORATIONS: Perforated? X Ves. T No.	with at least one entry for each change of forma	tion. Rep	port each	change in
	position of Static Water Level and indicate prin	cipal wa	iter-beari	ng strata.
Type of perforator used	MATERIAL	From	То	SWL
Size of perforations in. by in.	TOP Soil	0	2	
	BROWN CLAY	2	82	
perforations from ft. to ft.	BROWN CLAY WG IMBEDED	22	28	
perforations from ft. to ft.	_ (PAY SANY CLAY	28	36	
(7) SCREENS: Well screen installed? Ves 🕱 No	- Clery Clay	36	48	
Manufacturer's Name	BROWN CLAY	48	56	
Type	BEOWN SANDY CLAY	56	87	<u> </u>
Diam Slot size Set from ft. to ft.	BROWN SAND	87	95	··
Diam, Slot size Set from ft, to ft,	BROWN CLAY BROWN SAND - GENVEL	95	98	1 de la
	BLACK SAND	172	<u>123</u> 133	50
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	Geny CLAY	133	148	
Was a pump test made? 🕱 Yes 🗌 No If yes, by whom? Dr.2LER	Genyish BLUE CLAY	1219	162	
Viald: 150 gal./min. with 45 ft. drawdown after 316 hrs.	ORAY CLAY W/SAND STREAS	162	180	
			1.00	
Bailer test gal./min. with ft. drawdown after hrs.	-			
Artesian flow g.p.m.				
perature of water Depth artesian flow encountered ft.	Work started 10/17 19 73Complete	ed 🖊	0/24	1973
(9) CONSTRUCTION:	Date well drilling machine moved off of well	1	0124	19 73
Well seal-Material used RAW CEMENT	Drilling Machine Operator's Certification:		1	
	This well was constructed under my		t super	vision.
Well sealed from land surface to 30 ft.	Materials used and information reported			
Diameter of well bore to bottom of seal in.	best knowledge and belief.		10/01	12
Number of sacks of cement used in well seal	[Signed] Nichard L. Wright (Drilling Machine Operator)	Date	-/7	., 19.7.2
Number of sacks of bentonite used in well seal	Drilling Machine Operator's License No.		2	
Brand name of bentonite	-			
Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:			
of water	This well was drilled under my jurisdiction and this report is			
Was a drive shoe used? X Yes 🗆 No Plugs Size: location ft.	true to the best of my knowledge and belief.			
Did any strata contain unusable water? 🔲 Yes 🕅 No	Name JU Deck Well dilling (Person, firm or corporation) (Type or print)			
Type of water? depth of strata	Address 24137 S SKy line Prive Conty Ore 97013			
Method of sealing strata off				
	[Signed] John W Deck			
	(Water Well Contr			
Gravel placed from ft. to ft.	Contractor's License No. 44.9 Date	<u>cl.2</u>	ł	., 19
(USE ADDITIONAL SHEETS IF NECESSARY) SP*45656-119				