

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED
NOV 20 1972
STATE ENGINEER
SALEM, OREGON

State Well No. 55/1W-14 *cd*

State Permit No. _____

CLAC
02150

(1) OWNER:

Name Vernon Johnson
Address Rt 2 Box 117
Woodburn Ore

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded

6" Diam. from 0 ft. to 89 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____

Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 35 gal./min. with 27 ft. drawdown after 2 hrs.
Artesian flow g.p.m. _____

(9) CONSTRUCTION:

Well seal—Material used Grout
Well sealed from land surface to 32 ft.
Diameter of well bore to bottom of seal 9.5 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 3 sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Clackamas Driller's well number _____
SE 1/4 SW 1/4 Section 14 T. 53 R. 1W W.M.
Bearing and distance from section or subdivision corner
20ft from SE corner of House

(11) WATER LEVEL: Completed well.

Depth at which water was first found 70 ft.
Static level 47 ft. below land surface. Date 11-
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing _____

Depth drilled _____ ft. Depth of completed well _____ ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|------------------|------|----|-----|
| Top Soil | 0 | 2 | |
| Brown Clay | 2 | 18 | |
| Brown silt | 18 | 20 | 14 |
| Gray Clay | 20 | 36 | |
| (cement gravel) | 36 | 41 | |
| Dark clay & sand | 41 | 51 | |
| light Brown clay | 51 | 70 | |
| Brown sand | 70 | 73 | |
| Gravel | 73 | 89 | 47 |

Work started 13 1972 Completed 17 1972
Date well drilling machine moved off of well 17 1972

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] John W Beck Date 11-17, 1972
(Drilling Machine Operator)

Drilling Machine Operator's License No. 437

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name JW Beck Well Drilling Inc
(Person, firm or corporation) (Type or print)

Address 110 Sky Lane Dr Camby Ore 97013

[Signed] John W Beck
(Water Well Contractor)

Contractor's License No. 449 Date 11-27, 1972