

RECEIVED  
OCT 3 1966

CLAC  
02155

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE ENGINEER OF OREGON (Please type or print)

State Well No. 5/1w-14 M

State Permit No.

G-7269 (#1)

(1) OWNER:

Name Vern C. Johnson  
Address Rt 2, Woodburn, Oreg.

(2) LOCATION OF WELL:

County Clackamas Driller's well number  
Bearing and distance from section or subdivision corner  
1450ft N& 1000 ft E of SW cor of sec  
14 T.5 S. R 1 W. of W.M.

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other   
Rotary  Cable  Dug   
Driven  Jetted  Bored

(6) CASING INSTALLED:

Threaded  Welded   
8" Diam. from 0 ft. to 160 ft. Gage 250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used, Mix Mills  
Size of perforations 4 in. by 3 in.  
504 perforations from 103-160 ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name  
Model No.  
Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite&cuttings  
Depth of seal 20 ft. Was a packer used? yes  
Diameter of well bore to bottom of seal 13 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level 60 ft. below land surface Date 7/4/66  
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Driller  
Yield: 160 gal./min. with 79 ft. drawdown after 4 hrs.  
" " " " "  
" " " " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 8  
Depth drilled 218 ft. Depth of completed well 170 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil brn.	0	1
Clay brn.	1	12
Clay sandy brn.	12	40
Sand fine brn.	40	58
Clay sandy brn.	58	65
Med conglomerate tight	65	85
Sand fine brn.	85	93
Clay & mixed gravel brn.	93	103
Med conglom brn.	103	134
Looser gravel grey	134	136
Med conglom. grey	136	138
Clay grey	138	170
Soft claystone grey, cavy	170	218

Water coming from gravel 103 138

Hole caved back to 170 ft.

Work started 6/13 1966 Completed 7/4 1966  
Date well drilling machine moved off of well 7/4 1966

(13) PUMP:

Manufacturer's Name Jacuzzi  
Type: Turbine H.P. 20

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadel & Sons  
Address Rt 3 Box 169, Silverton, Oreg.

Drilling Machine Operator's License No. 84

[Signed] Paul R. Stadel  
(Water Well Contractor)

Contractor's License No. 296 Date 7/15 1966