

**NOTICE TO WATER WELL CONTRACTOR**

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

**RECEIVED WATER WELL REPORT**  
 JAN 7 1966  
 STATE OF OREGON  
 (Please type or print)

**CLAC**  
**02156**

State Well No. 5/1w-14 P  
 State Permit No. \_\_\_\_\_

**STATE ENGINEER**  
 SALEM OREGON

G 3339

**(1) OWNER:**

Name Harlod Ashland  
 Address Route 2, Box 113-A  
Woodburn, Oregon.

**(2) LOCATION OF WELL:**

County Clackamas Driller's well number \_\_\_\_\_  
 1/4 Section T. R. W.M.  
 Bearing and distance from section or subdivision corner  
3100 ft W, 300 ft N, of S.E. cor of  
sec 14, T.5.S, R.1.W, of W.M.

**(3) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
 Abandonment, describe material and procedure in Item 12.

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal  Irrigation  Test Well  Other   
 Rotary  Cable  Dug  Driven  Jetted  Bored

**(5) TYPE OF WELL:**

**(6) CASING INSTALLED:**

Threaded  Welded   
 8" Diam. from 0 ft. to 169 ft. Gage 250  
 " Diam. from " ft. to " ft. Gage "  
 " Diam. from " ft. to " ft. Gage "

**(7) PERFORATIONS:**

Perforated?  Yes  No  
 Type of perforator used Mills  
 Size of perforations 1/4 in. by 2 1/2 in.  
 216 perforations from 102 ft. to 120 ft.  
 92 perforations from 120 ft. to 166 ft.  
 perforations from " ft. to " ft.  
 perforations from " ft. to " ft.  
 perforations from " ft. to " ft.

**(8) SCREENS:**

Well screen installed?  Yes  No  
 Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
 Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Diam. Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Well seal—Material used in seal Bentonite & cuttings.  
 Depth of seal 18 ft. Was a packer used? no  
 Diameter of well bore to bottom of seal 12 in.  
 Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
 Was a drive shoe used?  Yes  No  
 Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
 Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
 Method of sealing strata off \_\_\_\_\_

**(10) WATER LEVELS:**

Static level 49 ft. below land surface Date 12-24-65  
 Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

**(11) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom? Drillers  
 Yield: 120 gal./min. with 109 ft. drawdown after 5 hrs.  
 " " " " "  
 " " " " "  
 Baller test XX gal./min. with \_\_\_\_\_ ft. drawdown after XX hrs.  
 Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
 Temperature of water XX Was a chemical analysis made?  Yes  No

**(12) WELL LOG:**

Diameter of well below casing 8  
 Depth drilled 190 ft. Depth of completed well 190 ft.  
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil, brn.	0	1
Clay, light brn.	1	20
Clay, sandy, brn.	20	32
Clay, sandy, grey.	32	58
Clay, sandy, grey, sticky.	58	72
Clay, sandy, brn.	72	78
Clay, sandy, grey.	78	102
Med congl, dark grey.	102	104
Loose gravel & sand, D. grey	104	107
Med congl, dark grey.	107	120
Clay, grey, sticky.	120	172
Clay, sandy, grey.	172	180
Clay, grey, sticky.	180	190

Work started \_\_\_\_\_ 19 \_\_\_\_\_ Completed Dec. 29, 1965  
 Date well drilling machine moved off of well Dec. 30, 1965

**(13) PUMP:**

Manufacturer's Name Jacuzzi  
 Type: TURBINE H.P. 10

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadel & Sons (Person, firm or corporation) (Type or print)  
 Address Rte. 3, Box 169, Silverton, Oregon  
 Drilling Machine Operator's License No. 84 & 322  
 [Signed] Paul R. Stadel (Water Well Contractor)  
 Contractor's License No. 296 Date 1/6/65 19 \_\_\_\_\_