

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JUN 20 1967

WATER WELL REPORT

STATE ENGINEER OF OREGON SALEM, OREGON (Please type or print)

CLACK 02180

State Well No. 5/1w-24 P

G-4004

State Permit No.

(1) OWNER:

Name Ross Iverson Address Route 2, Box 97 Woodburn, Oregon

(2) LOCATION OF WELL:

County Clackamas Driller's well number 1/4 Section T. R. W.M. Bearing and distance from section or subdivision corner 1275, N. 2130, E. of S.W. cor of Sec 24 . R.I.W. T5S.

(3) TYPE OF WORK (check):

Well [X] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other [] Rotary [X] Driven [] Cable [] Jetted [] Dug [] Bored []

(5) TYPE OF WELL:

(6) CASING INSTALLED:

18" Diam. from 0 ft. to 18 ft. Gage 250 8" Diam. from 0 ft. to 180 ft. Gage 250

(7) PERFORATIONS:

Perforated? [X] Yes [] No Type of perforator used Torch Size of perforations 1/8 in. by 1 ft. in. 54 perforations from 18 ft. to 60 ft. 54 perforations from 140 ft. to 160 ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement Depth of seal 18 ft. Was a packer used? no Diameter of well bore to bottom of seal 22 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [] Yes [X] No Was well gravel packed? [X] Yes [] No Size of gravel: 3/8 to 1/8 Gravel placed from 0 ft. to 180 ft. Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level Flowing 1ft. above surface ft. below land surface Date 4/12/67 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [] No If yes, by whom? Driller Yield: 108 gal./min. with 50 ft. drawdown after 6 hrs.

(12) WELL LOG:

Diameter of well below casing 0

Depth drilled 180 ft. Depth of completed well 175

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries include Top soil, black; Clay, grey; Med congl. brn; Clay, grey; Med congl, grey; Clay, grey; Clay, sandy, gritty, grey; Sandy, Clay, grey, with streaks of sand.

Work started 3/21/67 19 Completed 4/12/67 19 Date well drilling machine moved off of well 4/12/68 19

(13) PUMP:

Manufacturer's Name J. a. cuzzani Type: S.A.B. H.P. 10

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadeli & Sons (Person, firm or corporation) (Type or print) Address Route 3, Box 169, Silverton

Drilling Machine Operator's License No. 84

[Signed] Paul R. Stadeli (Water Well Contractor)

Contractor's License No. 296 Date 4/13/67 19