

RECEIVED
SEP 25 1961

STATE ENGINEER WATER WELL REPORT
SALEM, OREGON STATE OF OREGON

CLAC State Well No. 5/1W-24 JG (1)
02181 State Permit No.

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

(1) OWNER:

Name Wm. H. Schroeder
Address 512 1/2 Rd 99
Gradburn Oregon

(2) LOCATION OF WELL:

County Clackamas Owner's number, if any—
NE 1/4 S13 1/4 Section 24 T. 55 R. 1 W. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8" Diam. from 1 ft. to 102 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used _____
SIZE of perforations in. by in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 25 ft.
Material used in seal— Reddell clay
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 34 ft. below land surface Date Sept 4, 1961
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:

[Signed] Wm. H. Schroeder Date Sept 6, 1961
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? _____
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 40 gal./min. with 50 ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 54 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well _____ inches.
Depth drilled 132 ft. Depth of completed well 115 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
top soil	0	1
brown clay	1	20
blue clay	20	32
brn. clay	32	36
sandy brown clay	36	38
medium sand, medium	38	51
gravel & clay		
tan clay	51	63
greyish blue clay	63	67
black clay	67	68
med. brown sand (30 gal	68	72
min static level 37 1/2)		
tan clay	72	76
medium gravel & clay	76	79
tan clay	79	81
blue clay	81	87
sandy blue clay	87	102
black sand no gravel	102	105
blue clay	105	120
green clay	120	128
sandy clay (soft)	128	132
blue clay	132	132

Work started Aug 25 1961. Completed Sept 4 1961

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME C. G. Westerberg
(Person, firm, or corporation) (Type or print)

Address Rt 1 Box 151 Muldoon Ore

Driller's well number 296

[Signed] C. G. Westerberg
(Well Driller)

License No. PL Date Sept 6, 1961