

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 OCT 1 1965 STATE OF OREGON (Please type or print)

STATE ENGINEER

63505

State Well No. 5/1-7 L

State Permit No.

(1) OWNER:

Name George Yoder  
Address Rte 1 Box 181  
Hubbard, Oregon

(2) LOCATION OF WELL:

County Clackamas Driller's well number  
1/4 Section 7 T. 5S R. 1E W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other   
Rotary  Cable  Dug   
Driven  Jetted  Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded  Welded   
8" Diam. from 0 ft. to 135 ft. Gage 1 1/2"  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No

Type of perforator used Millknife  
Size of perforations 3/8 in. by 2 in.  
64 perforations from 103 ft. to 107 ft.  
32 perforations from 112 ft. to 114 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name  
Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Puddled Mud  
Depth of seal 24 ft. Was a packer used? no  
Diameter of well bore to bottom of seal 12 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level 40 ft. below land surface Date 9/14/65  
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? driller  
Yield: 180 gal./min. with 26 ft. drawdown after 2 hrs.  
" 200 " " 28 " " 2 "  
" " " " " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing

Depth drilled 135 ft. Depth of completed well 135 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| MATERIAL               | FROM | TO  |
|------------------------|------|-----|
| Surface                | 0    | 4   |
| Brown sandy clay       | 4    | 21  |
| Blue sandy clay        | 21   | 60  |
| Coarse sand and gravel | 60   | 64  |
| Sand                   | 64   | 65  |
| Coarse sand and gravel | 65   | 69  |
| Sticky blue clay       | 69   | 78  |
| Brown sandy clay       | 78   | 89  |
| Broken sand and gravel | 89   | 92  |
| Blue sandy clay        | 92   | 102 |
| Gravel                 | 102  | 105 |
| Brown clay             | 105  | 112 |
| Gravel                 | 112  | 114 |
| Blue clay              | 114  | 131 |
| Sand                   | 131  | 132 |
| Blue clay              | 132  | 135 |

Work started Sept 7 1965 Completed Sept 14 1965  
Date well drilling machine moved off of well Sept 14 1965

(13) PUMP:

Manufacturer's Name  
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Truman Miller  
(Person, firm or corporation) (Type or print)

Address P O Box 42 Hubbard, Oregon

Drilling Machine Operator's License No. 277 26

[Signed] John T. Miller  
(Water Well Contractor)

Contractor's License No. 277 26 Date Sept 14, 1965

