NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON

(Please type or print) (Do not write above this line)

RECEIVED APR 20 1977 WATER RESOURCES DEPT. SALEM, OREGON

State Well No. 5S/1E-8

State Permit No.

02393 CLAC

(1) OWNER:
Name Aksinia Sanoilov
Address 31372 S. Mody Rd.
Canby, Oregon 97013

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:
Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 110 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:
Perforated? ☐ Yes ☒ No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 50 gal./min. with 25 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 54 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to 28 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal sacks
Number of sacks of bentonite used in well seal 11 sacks
Brand name of bentonite National
Number of pounds of bentonite per 100 gallons of water 200 lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Clackamas Driller's well number
¼ ¼ Section 3 T. 5S R. 1E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 122 ft.
Static level 40 ft. below land surface. Date 4-15-77
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6"
Depth drilled 123 ft. Depth of completed well 125 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Soil brown	0	3	
Clay brown	3	33	
Clay grey	33	44	
Clay brown	44	52	
Gravel brown	52	75	
Clay brown	75	100	
Sandy clay blue	100	110	
Clay dark grey	110	122	
Gravel with sand grey WB	122	123	40

Work started 4-13 19 77 Completed 4-15 19 77
Date well drilling machine moved off of well 4-15 19 77

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Robert Stites (Drilling Machine Operator) Date 4-16, 19 77
Drilling Machine Operator's License No. 776

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name A C Stites (Person, firm or corporation) (Type or print)
Address 22284 S. Leyland Rd. Canby, Oregon
[Signed] A C Stites (Water Well Contractor)
Contractor's License No. 533 Date April 16, 19 77

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119