NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JUL 3 1964

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

02422
CLAC

State Well No. 5/1-9
State Permit No.

(1) OWNER:
Name Nels Sanden,
Address Rt,2,Box 161,Canby,Ore.

(2) LOCATION OF WELL:
County Clack. Driller's well number
¼ ¼ Section 9 Twp 5s R. 1r W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:
Threaded ☐ Welded ☒
8" Diam. from 0 ft. to 135 ft. Gage 1/4
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used mill knife
Size of perforations zig zag by in.
81 perforations from 38 ft. to 49 ft.
64 perforations from 63 ft. to 71 ft.
24 perforations from 86 ft. to 89 ft.
56 perforations from 115 ft. to 120 ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed? ☐ Yes ☐ No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal cement and bentonite
Depth of seal 20 ft. Was a packer used?
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? ☐ Yes ☐ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Was well gravel packed? ☒ Yes ☐ No Size of gravel: 3/4min,P
Gravel placed from 20 ft. to 135 ft.
Did any strata contain unusuable water? ☐ Yes ☐ No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 23 ft. below land surface Date 7-1st64
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? J.T.Miller
Yield: 250 gal./min. with 100 ft. drawdown after 5 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG:
Diameter of well below casing 8
Depth drilled 178 ft. Depth of completed well 178 ft.

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
surface	0	3
clay,brown	3	25
" ",blue	25	35
sand,gravel black	35	49
clay,gray	49	63
gravel and sand	63	71
clay,gray	71	75
hard sand,red	75	77
sandy clay,brown	77	86
coarse sand,red	86	89
clay,brown	89	115
gravel,black	115	120
clay,blue	120	135
clay,gray	135	147
clay,brown	147	161
conglomerate,brown,blu,gray	161	178
completed pumping		

Work started 6-8th- 1964. Completed 7-1st 1964
Date well drilling machine moved off of well 6-22- 1964

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.T.Miller (Person, firm or corporation) (Type or print)
Address Box 175, Aurora,Ore.
Drilling Machine Operator's License No. 191
[Signed] J T Miller (Water Well Contractor)
Contractor's License No. 7 Date 8-1st., 1964

(USE ADDITIONAL SHEETS IF NECESSARY)