

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

RECEIVED

SEP 24 1973

55/E-20 19da

STATE ENGINEER, SALEM, OREGON 97330 within 30 days from the date of well completion.

CLAC 02573

STATE OF OREGON (Please type or print)

STATE ENGINEER SALEM, OREGON

State Well No.

State Permit No.

Cord in use 2190

(1) OWNER:

Name Gregory Amphiloieff Address Rt 2 Box 180 RR Woodburn Ore

(2) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [x] Industrial [] Municipal [] Irrigation [x] Test Well [] Other []

CASING INSTALLED:

Threaded [] Welded [x]

8" Diam. from 0 ft. to 230 ft. Gage 250

PERFORATIONS:

Perforated? [x] Yes [] No

Type of perforator used Star Size of perforations 3/8 in. by 2 in. 220 perforations from 47 ft. to 58 ft. 50 perforations from 108 ft. to 118 ft. 50 perforations from 135 ft. to 140 ft. 50 205 211

(7) SCREENS:

Well screen installed? [] Yes [x] No

Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [x] Yes [] No If yes, by whom? Driller Yield: 110 gal./min. with 70ft. drawdown after 6 hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal-Material used Raw Cement Well sealed from land surface to 30 ft. Diameter of well bore to bottom of seal 12 in. Diameter of well bore below seal 8 in. Number of sacks of cement used in well seal 5 sacks Number of sacks of bentonite used in well seal Brand name of bentonite Number of pounds of bentonite per 100 gallons of water lbs./100 gals. Was a drive shoe used? [x] Yes [] No Plugs Size: location ft. Did any strata contain unusable water? [] Yes [x] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Clatsop Driller's well number SW 1/4 Sec 20 T. 53 R. 1E W.M. Bearing and distance from section or subdivision corner North of House in field

(11) WATER LEVEL: Completed well.

Depth at which water was first found 47 ft. Static level 27 ft. below land surface. Date 9/12/73 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8"

Depth drilled 300 ft. Depth of completed well 300 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include: Top Soil (0-2), Gray Clay (2-19), Brown Clay w/ Imbedded (19-47), Cement Gravel (47-58), Brown Clay (58-63), Grayish Blue Sandy Clay (63-85), Brown Clay (85-94), Gray Clay w/ Imbedded (94-101), Brown Clay (101-108), Shale (108-118), Gray Clay (118-123), Light Brown Clay (123-132), Gray Sandy Clay (132-141), Black Silt (141-146), Brown Clay (146-158), Gray Sandy Clay (158-196), Grayish Blue Clay (196-213), Black Silt (213-218), Gray Clay (218-259), Black Silt (259-300)

Work started 8/24 19 73 Completed 9/13 19 73 Date well drilling machine moved off of well 9/13 19 73

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Richard L. Wright Date 9/13, 1973 (Drilling Machine Operator)

Drilling Machine Operator's License No. 762

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name J.W. Beck Well Drilling (Person, firm or corporation) (Type or print)

Address 24131 S. Skye Dr. Conby Ore

[Signed] John W. Beck (Water Well Contractor)

Contractor's License No. 4119 Date Sept 19, 1973