STATE OF OREGON

RECEIVE

STATE OF OREGON	(02617 "C)	2 1 10 c		
WATER WELL REPORT MAY 1 6 1985 (as required by ORS 537.765) WATER RESOURCES ALEH, OREGON ONLY OF THE PORT OF THE PROPERTY OF THE PORT OF		Į.		
(as required by ORS 537.765 MATER RESOURCE	PRINT IN INK (for official use only)			
(1) OWNER:				
(I) OWNER:	(10) LOCATION OF WELL by legal description:			
Name Crest View Farms- Charlie Lucht	County Clackamas NE 4 NW 4 of Section 23 of Township 5south , Range 1 east , WM.			
Address 33366 S. Dryland Rd.	Township 5 SOU $\frac{1}{1}$, Range $\frac{1}{1}$	CaS U Range is East or West	, WM.	
City Molalla, Oregon 97038 State	Tax Lot Lot Block Subdivision			
(2) TYPE OF WORK (check):	MAILING ADDRESS OF WELL (or nearest address)			
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐	Same as owner			
If abandonment, describe material and procedure in Item 12.				
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL of COMPLETED WELL:			
Rotary Air Driven Domestic Industrial Municipal	Depth at which water was first found 207 ft.			
Thermal:	Static level 87 ft. below land surface. Date 5/13/85			
Other:		square inch. Date	<u> </u>	
Bored Piezometric Grounding Test	(12) WELL LOG: Diameter of well below casing 8"			
5) CASING INSTALLED: Steel	Depth drilled 380 ft. Depth of completed welf 380 ft.			
Threaded \square Welded X_{\square}	Formation: Describe color, texture, grain size and structure of materials; and show thickness			
8 Diam. from +2 ft. to 263 ft. Gauge 250	and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal			
ft. toft. Gauge	water-bearing strata.			
LINER INSTALLED: Steel Plastic Welded Welded	MATERIAL	From To	SWL	
Timedada = William =	Top soil	0 1		
ft. toft. Gauge	Clay brown	1 33		
(6) PERFORATIONS: Perforated? ☐ Yes ☒ No	Clay grey	33 61		
Size of perforations in. by in.	Claystone grey-blue crmbl	61 102		
ft. to ft.	Ash grey	102 113		
perforations from ft. to ft.	Clat yellow sticky	113 161		
perforations from ft. to ft.	Clay grev	161 182		
(7) SCREENS: Well screen installed? ☐ Yes ☑ No	Clay grey sticky	182 207		
Manufacturer's Name	Sand grey-green course			
Type	packed	207 212		
Diam. Slot Size Set from ft. to ft.	Clay grey sticky	212 234		
Diam. Slot Size Set from ft. to ft.	Claystone grey-brn. crmbl	234 253	1.17	
Drawdown is amount water level is lowered	Basalt green and grey	253 291	WB	
(8) WELL TESTS: below static level	Basalt with blue clay			
Was a pump test made? 🔲 Yes 🔯 No If yes, by whom?	streaks	291 312		
d: gal./min. with ft. drawdown after hrs.	Basalt grey	312 354	Telep	
n n	Basalt with white streaks	354 368	WB	
Air test 450 gal./min. with drill stem at 260t. 1 hrs.	Basalt grey hard	368 380		
Bailer test gal./min. with ft. drawdown after hrs.				
Artesian flow g.p.m.				
operature of water Depth artesian flow encountered ft.	Date work started 5/7/85 /complete	ed 5/11/8	5	
(9) CONSTRUCTION: Special standards: Yes \(\subseteq \) No \(\subseteq \)	Date well drilling machine moved off of well 5/13/85 19			
Well seal—Material used	(unbonded) Water Well Constructor Certification (if applicable):			
Well sealed from land surface to 40' 253'-263' ft.	This well was constructed under my direct supervision. Materials used and			
Diameter of well bore to bottom of seal in.	information reported above are true to my best knowledge and belief.			
Diameter of well bore below seal	Men of that. O.	[Signed] Sleven M. Stabli Date 5-14 , 19 83		
Amount of sealing material 22 sacks pounds Thumps of those 21 nine				
How was cement grout placed? Pumped thru 2" pipe	(bonded) Water Well Constructor Certification:			
	Bond Issued by: <u>Union Indemnity</u> (Surety Company Name)			
NO	On behalf of West Coast Drilling Chuck Stadeli			
Was pump installed? NO Type HP Depth ft.	(type or must name of Water Well Constructor)			
Was a drive shoe used?	This well was drilled under my jurisdiction and this report is true to the			
Type of Water? depth of strata	best of my knowledge and belief:			
	(Signed) he for			
Method of sealing strata off Was well gravel packed? ☐ Yes XIX No Size of gravel:	(Water Well Constructor)			
Was well gravel packed? Yes XIX No Size of gravel:	(Dated) 5-14-85			
Gravei placed from It. to It.	<u> </u>			