

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the State Engineer, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

State Well No. 51-25(1)

State Permit No. _____

GLAC
02649
2270

(1) OWNER:

Name: Rudolph Leo Schnack
Address: Route 3, Box 330, Molalla

(2) LOCATION OF WELL:

County: CLATSOP Driller's well number: _____
Section: 25 T. 5 R. 1E W.M.
Bearing and distance from section or subdivision corner

90 rods west of the North West corner of section 25 then 500 FT south of section line between section 25 and 24

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 33'3" ft. Gage 9"
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used _____
Size of perforations in. by in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____ Model No. _____
Type _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE
Depth of seal 25 ft. Was a packer used? GRAVEL
Diameter of well bore to bottom of seal _____ in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 156 ft. below land surface Date _____
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? TRACTOR AND IMPLEMENT, SWEETEN, OKE
Yield: 350 gal./min. with 6 ft. drawdown after 5 hrs.
" " " " " " " "
" " " " " " " "
Bailer test 21 gal./min. with NO ft. drawdown after 2 hrs.
Artesian flow _____ e.p.m. Date _____
Temperature of water 59 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 8"
Depth drilled 352 ft. Depth of completed well 352 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
CLAY AND BOULDERS	0	26
IGNEOUS GREY HARD BASALT	26	51
BASALT	51	55
SOFT BROWN ROCK	55	101
HARD GREY BASALT	100	110
BROWN ROCK	110	142
HARD GREY BASALT	142	160
BROWN SHALE	142	161
HARD GREY BASALT	160	210
STATIC W/ LEVEL FROM SEEP		
HARD GREY BASALT	210	325
HONEYCOMBED LAVA	325	346
WATER BEARING		
STATIC CHANGED TO 156		
HARD GREY BASALT	346	352

Work started 26-20 1962 Completed April 19 1962
Date well drilling machine moved off of well NOT YET 19

(13) PUMP:

Manufacturer's Name NONE
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLIAM J. STEINNETT
(Person, firm or corporation) (Type or print)
Address 361 WARNER MILNE RD OREGON CITY
Drilling Machine Operator's License No. _____
[Signed] William J. Steinnett
(Water Well Contractor)
Contractor's License No. 57 Date APR 11 24, 1962