

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

RECEIVED WATER WELL RECEIVED RECEIVED
STATE OF OREGON JAN 24 1977
FEB 4 1977
(Do not write above this line)

State Well No. 5/12/211

State Permit No. _____
WATER RESOURCES DEPT.
SALEM, OREGON

(1) OWNER:

Name Bernard Kimlinger
Address Rt 3 box 300 a Molalla

(10) LOCATION OF WELL:

County Clackamas Driller's well number _____
S.E. 1/4 S.E. 1/4 Section 27 T. 5s R. 1E W.M.
bearing and distance from section or subdivision corner _____

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

(4) PROPOSED USE (check):

Rotary Driven Domestic Industrial Municipal
Cable Jetted Irrigation Test Well Other
Dug Bored

CASING INSTALLED:

Threaded Welded

6" Diam. from 0 ft. to 72 ft. Gage .250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____
Size of perforations in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Type _____ Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" " " " " "
Air
Baller test 75 gal./min. with 95 ft. drawdown after 3 hrs.
Artesian flow _____ g.p.m.

(11) WATER LEVEL: Completed well.

Depth at which water was first found 128 ft.
Static level 37 ft. below land surface. Date 1-18-77
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6 ft.

Depth drilled 163 ft. Depth of completed well 163 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top soil ban	0	1	
Clay ban	1	19	
Broken rock grey	19	27	
clay grey	27	41	
M. Claystone	41	98	
H. Basalt grey	98	128	
M.H. Seamy Basalt	128	132	W.B.
H. Basalt grey	132	157	W.B.
S. Claystone grey	157	163	

Work started 1-8 19 77 Completed 1-18 1977
Date well drilling machine moved off of well 1-18 19 77

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Charles Stadel Date 1-21, 1977.
(Drilling Machine Operator)

Drilling Machine Operator's License No. 84

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Stadelti Drilling Company
(Person, firm or corporation) (Type or print)
Address Mr. Angel Dr
[Signed] Charles Stadel
(Water Well Contractor)

Contractor's License No. 519 Date 1-21, 1977