NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED ... 8 1968 ... ENGINEER ... SON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

CLAC 02700

State Well No. 5/1-29 L

State Permit No. G-4354

(1) OWNER:
Name Bill Bonser
Address Rt 2 Box 224, Woodburn, Oreg.

(2) TYPE OF WORK (check):
New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [X] Driven []
Cable [] Jetted []
Dug [] Bored []

(4) PROPOSED USE (check):
Domestic [] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []

CASING INSTALLED:
Threaded [] Welded [X]
20 " Diam. from 0 ft. to 20 ft. Gage .250
10 " Diam. from 0 ft. to 224 ft. Gage .250
" Diam. from ft. to ft. Gage

PERFORATIONS:
Perforated? [X] Yes [] No
Type of perforator used Torch
Size of perforations 1/4 in. by 6 in.
36 perforations from 215 ft. to 224 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? [] Yes [X] No
Manufacturer's Name Johnson
Type 10" Irrigater Model No. #100 slot
Diam. Slot size #100 Set from 97 107 ft. to ft.
Diam. 10" Slot size #100 Set from 143 ft. to 163 ft.
#100 205 -- 215

(8) WATER LEVEL: Completed well.
Static level 50 ft. below land surface Date 3/13
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [X] No If yes, by whom? Driller
50 gal./min. with 125 ft. drawdown after 8 hrs.
" " " "
" 300 " 97 " 8 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [] Yes [] No

(10) CONSTRUCTION:
Well seal—Material used cement
Depth of seal 20 ft.
Diameter of well bore to bottom of seal 24 in.
Were any loose strata cemented off? [] Yes [X] No Depth
Was a drive shoe used? [] Yes [X] No
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [X] Yes [] No Size of gravel 3/8 pea
Gravel placed from 0 ft. to 224 ft.

(11) LOCATION OF WELL:
County Clackamas Driller's well number
¼ ¼ Section T. R. W.M.
Bearing and distance from section or subdivision corner
Approx. 2500 ft N. &2050 ftE. of S.W. cor sec 29, T 5 S R 1 E

(12) WELL LOG:
Diameter of well below casing none
Depth drilled 224 ft. Depth of completed well 224 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top soil brn.	0	1½	
Clay	1½	12	
Clay blue	12	26	
Loose sand & gravelsmall	26	28	
Clay brn.	28	31	
Med sand&few small gravel	31	39	
Clay L. brn	39	44	
Clay grey	44	55	
Clay brn.	55	72	
Clay blue	72	79	
Clay brn.	79	99	
Clay D. grey	99	102	
Sand fine blue W.B.	102	105	
Clay grey	105	134	
Sand fine blue green W.B.	134	135	
Clay gritty B-Green	135	139	
Clay grey	139	145	
Course sand black W.B.	145	158	
Clay grey	158	192	Clay
Clay blue	192	198	grey
Dirty sandfine blue	198	200	215 224
Clay blue	200	208	
Med sand blk W.B.	208	215	

Date started 3/13 19 68 Completed 3/13 19 68
Date well drilling machine moved off of well 3/13/68 19

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] C. E. Stadeli (Drilling Machine Operator) Date 3/25, 1968
Drilling Machine Operator's License No. 84

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME R. Stadeli & Sons (Person, firm or corporation) (Type or print)
Address Rt 3 Box 169, Silverton, Oreg.
[Signed] Paul R. Stadeli (Water Well Contractor)
Contractor's License No. 296 Date 3/25, 1968

(USE ADDITIONAL SHEETS IF NECESSARY)