

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM 10, OREGON
within 30 days from the date
of well completion.

RECEIVED
NOV 19 1962
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

02721
CLAC
G-4778

State Well No. 5/1-30N
State Permit No.

(1) OWNER:

Name William J. Dahlkeil
Address R2-B-253
Woodburn, ORE

(2) LOCATION OF WELL:

County MARION Driller's well number
S.W. 1/4 SW 1/4 Section 30 T. 5. S R. 1. E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 108 ft. Gage 1200
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE
Depth of seal 18 ft. Was a packer used?
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: 1/4 - 1/2"
Gravel placed from 102 ft. to 115 ft.
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 6 ft. below land surface Date 11/15/62
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
" " " " "
Baller test 40 gal./min. with 10 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water 54 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 115 ft. Depth of completed well 110 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOPSOIL	0	4
BROWN CLAY WITH SOME GRAVEL	4	12
BROKEN LAVA BLACK SOFT STICKY BLUE CLAY	12	18
BLUE SANDY CLAY	18	60
STREAKS OF CLAY AND CLAY FINE	60	85
SOME CLAY AND SAND	85	105
SMALL AMOUNT OF GRAVEL	105	110
WATER BEARING	105	110

Work started NOV 7 1962 Completed NOV 15 1962
Date well drilling machine moved off of well NOV 16 1962

(13) PUMP:

Manufacturer's Name BERKELEY
Type: SUB H.P. 3

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLIAM D. STENNETT
(Person, firm or corporation) (Type or print)
Address 361 WARNER MILNER RD
Drilling Machine Operator's License No. 171
[Signed] William J. Stennett
(Water Well Contractor)
Contractor's License No. 50 Date NOV 16, 1962