

STATE OF OREGON  
**WATER WELL REPORT**  
 (as required by ORS 537.765)

**RECEIVED**

JAN 03 1986

PLEASE TYPE or PRINT IN INK

02736  
 CLAC

59/E-32a

(for official use only)

**WATER RESOURCES DEPT**

**(1) OWNER:**

Name **Roma J. Vosgien**  
 Address **7916 Monte Cristo Rd.**  
 City **Woodburn** State **OR. 97071**

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
 If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary Air  Driven   
 Rotary Mud  Dug   
 Cable  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
 Thermal: Withdrawal  Reinjection   
 Other: Piezometric  Grounding  Test

**(5) CASING INSTALLED:**

Steel Threaded  Plastic Welded   
 6" Diam. from +1 ft. to 126 ft. Gauge .250

**(6) LINER INSTALLED:**

Steel Threaded  Plastic Welded

**(7) PERFORATIONS:**

Perforated?  Yes  No  
 Size of perforations  $\frac{3}{4}$  in. by 2 in.  
 300 perforations from 84 ft. to 104 ft.

**(8) SCREENS:**

Well screen installed?  Yes  No  
 Manufacturer's Name ..... Model No. ....  
 Type .....  
 Diam. .... Slot Size ..... Set from ..... ft. to ..... ft.  
 Diam. .... Slot Size ..... Set from ..... ft. to ..... ft.

**(9) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom?  
 Yield: gal./min. with ft. drawdown after hrs.  
 Air test 7 gal./min. with drill stem at 94 ft. 3 hrs.  
 Bailer test gal./min. with ft. drawdown after hrs.  
 Artesian flow g.p.m.  
 Temperature of water Depth artesian flow encountered ..... ft.

**(10) CONSTRUCTION:**

Special standards: Yes  No   
 Well seal—Material used **Bentonite**  
 Well sealed from land surface to ..... ft.  
 Diameter of well bore to bottom of seal 10 in.  
 Diameter of well bore below seal 10 in.  
 Amount of sealing material 12 sacks  pounds   
 How was cement grout placed? **Bentonite was poured**  
 Was pump installed? **no** Type ..... HP ..... Depth ..... ft.  
 Was a drive shoe used?  Yes  No Plugs ..... Size: location ..... ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of Water? depth of strata .....  
 Method of sealing strata off .....  
 Was well gravel packed?  Yes  No Size of gravel: 3/8 X 3/4  
 Gravel placed from 20 ft. to 126 ft.

**(10) LOCATION OF WELL by legal description:**

County **Clackamas** NE  $\frac{1}{4}$  NE  $\frac{1}{4}$  of Section **32** of  
 Township **5 S**, Range **1 E**, WM.  
 (Township is North or South) (Range is East or West)  
 Tax Lot ..... Lot ..... Block ..... Subdivision .....  
 MAILING ADDRESS OF WELL (or nearest address) .....

**(11) WATER LEVEL of COMPLETED WELL:**

Depth at which water was first found **84** ft.  
 Static level **42** ft. below land surface. Date **12-14-85**  
 Artesian pressure lbs. per square inch. Date .....

**(12) WELL LOG:**

Diameter of well below casing **0**  
 Depth drilled **126** ft. Depth of completed well **126** ft.  
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	1	
Clay	1	8	
Rock	8	15	
Clay	15	84	
Clay with seams of sand	84	104	42
Clay	104	126	

Date work started **11-27-85** /completed **12-14-85**  
 Date well drilling machine moved off of well **12-16 19 85**

**(unbonded) Water Well Constructor Certification (if applicable):**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] ..... Date ....., 19 .....

**(bonded) Water Well Constructor Certification:**

Bond **9497479** Issued by: **Fidelity & Deposit Co.**  
 (number) (Surety Company Name)  
 On behalf of **Donnelly Drilling Co.**  
 (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

(Signed) **David Donnelly**  
 (Water Well Constructor)

(Dated) **12-26-85**

NOTICE TO WATER WELL CONSTRUCTOR  
 The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,  
 SALEM, OREGON 97310  
 within 30 days from the date of well completion.

SP\*46866-690