NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED
MAR 6 1974
STATE ENGINEER
SALEM, OREGON

CLAC 02747

66 46

State Well No. 5S/1E-32

State Permit No. 36167

(1) OWNER:

Name Gregory Sanarov

Address Rt2 Box241 Woodburn,Oreg

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [X] Driven []
Cable [X] Jetted []
Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []

CASING INSTALLED:

Threaded [] Welded [X]

[illegible]" Diam. from [illegible] ft. to 327 ft. Gage .250

6 " Diam. from 300 ft. to 360 ft. Gage .250

" Diam. from ft. to ft. Gage

PERFORATIONS:

6" liner
Perforated? [X] Yes [] No.

Type of perforator used torch

Size of perforations 1/2 in. by 12 in.

48 perforations from [illegible] ft. to 358 ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [] No If yes, by whom? Driller

Yield: 75 gal./min. with 147 ft. drawdown after 3 hrs.

" " "

" " "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

[illegible]perature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Bentonite& puddled clay

Well sealed from land surface to 327 ft.

Diameter of well bore to bottom of seal 12"to 20"10"to 327 in.

Diameter of well bore below seal 10" in.

Number of sacks of cement used in well seal sacks

Number of sacks of bentonite used in well seal 3 sacks

Brand name of bentonite national

Number of pounds of bentonite per 100 gallons of water 100 lbs./100 gals.

Was a drive shoe used? [X] Yes [] No Plugs Size: location ft.

Did any strata contain unusable water? [] Yes [X] No

Type of water? some salt depth of strata

Method of sealing strata off

Was well gravel packed? [] Yes [X] No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Clackamas Driller's well number

N.W. 1/4 S.E. 1/4 Section 32 T. 5.S. R. 1.E. W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 23 ft.

Static level 53 ft. below land surface. Date 1/26/74

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing none

Depth drilled 360 ft. Depth of completed well 360 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Top soil brn.	0	1	
Clay brn.	1	17	
Clay grey	17	20	
Clay brn.	20	23	
Pea gravel med. brn.	23	26	
Clay brn .	26	63	
Clay grey	63	128	
Clay sandy grey	128	142	
Clay grey sticky	142	276	
Clay brn.	276	320	
M.sandstone green	320	344	
H. sandstone green&blk.steaks	344	360	

Work started 10/11/73 19 Completed 1/26/74 19

Date well drilling machine moved off of well 1/26/74 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] C. E. Stadeli (Drilling Machine Operator) Date 2/4/74, 19

Drilling Machine Operator's License No. 84

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name R. Stadeli& Sons Inc. (Person, firm or corporation) (Type or print)

Address Silverton, Oreg

[Signed] Paul R. Stadelli (Water Well Contractor)

Contractor's License No. 296 Date 2/4/74, 19

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119