

RECEIVED  
SEP 6 1960

CLAC 02973

2/1-3R (1)

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE ENGINEER WATER WELL REPORT  
STATE OF OREGON

State Well No. \_\_\_\_\_  
State Permit No. \_\_\_\_\_

G1914

SEP 6 1960 FORMS

(1) OWNER:

Name Oswego Shopping Center  
Address Oswego Oregon.

(2) LOCATION OF WELL:

County Clatsop Owner's number, if any—  
1/4 1/4 Section T. R. W.M.  
Bearing and distance from section or subdivision corner  
Blk 137 Extension of Oregon  
Iron & Steel Companies 1st  
Add to Oswego.

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

12" " Diam. from 0 ft. to 155 ft. Gage std.  
" " Diam. from ft. to ft. Gage  
" " Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used \_\_\_\_\_  
SIZE of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from none ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:

Well screen installed  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Was a surface seal provided?  Yes  No To what depth? \_\_\_\_\_ ft.  
Material used in seal—  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:

Static level 120 ft. below land surface Date Aug 26 60  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_  
Log Accepted by: \_\_\_\_\_  
[Signed] \_\_\_\_\_ Date \_\_\_\_\_, 19\_\_\_\_  
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? B&S  
Well: 630 gal./min. with 15 ft. drawdown after 5 1/2 hrs.  
" " " " " "  
" " " " " "  
Ballor test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date \_\_\_\_\_  
Temperature of water 53 Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well 12 inches.  
Depth drilled 304 ft. Depth of completed well 304 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>Boulders</u>	<u>0</u>	<u>22</u>
<u>clay</u>	<u>22</u>	<u>120</u>
<u>Blue clay</u>	<u>120</u>	<u>155</u>
<u>Rock crevasse tough going</u>	<u>155</u>	<u>304</u>
<u>showing of water at</u>	<u>185</u>	
	<u>215</u>	
	<u>300</u>	
<u>Cuttings Black from</u>	<u>155 to 304</u>	

Work started Aug July 21 60 Completed Aug 26 1960

(13) PUMP:

Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Oswego Shopping Center.  
(Person, firm, or corporation) (Type or print)

Address Oswego Ore

Driller's well number \_\_\_\_\_

[Signed] Lance Strayer  
(Well Driller)

License No. 35 Date Aug 30, 1960.